HELIOVOLT - FIELD MAINTENANCE LOG * SCANNED 2026-02-14 *

Site: Acme Logistics Warehouse - Austin (org acme-hq-042)

Date: Feb 12, 2026 Technician: R. Alvarez (ID HV-0311) Ticket SUP-88231

Device: VoltGrid Controller X500 Serial: VG-X5-008812 Firmware: 1.9.2

Issue: Blinking amber LED - CT clamps reversed on L1/L2. Offline in dashboard.

Action: Swapped L1/L2 CT clamps. Allowed outbound MQTT mqtt.heliovolt.fake:8883

on firewall. Re-provisioned via installer app with 8-digit PIN 48291037.

Meter readings: L1 118.7 A / L2 121.3 A / Volts 241.2 V / Watts 3420 W / kWh today 28.4

Result: Solid green LED. Telemetry every 10 sec OK. RMA RMA-2026-1047 CLOSED.

Next visit: May 12, 2026 for EcoPulse batch EP-2025-001234 calibration (+-0.3C).

Signed: R. Alvarez _____ Supervisor: Aisha Khan _____

Note: C-wire adapter HV-ADP-24V installed on EcoPulse #14 (fixed E-14).

Depot return: Bldg B-4400 Helios Way. Support +1-512-555-0147.