

Sl no.	Description of work	Frequency (Per year)	Sample Location	Parameters (Each location)	No of Parameters (Each location)
1	Stack Emission (Unit-1)	Monthly	2	PM, SO _x , NO _x , CO ₂ , Hg, Oxygen, Flue gas Temp., Exit Velocity, Gas quantity (Volumetric flow rate)with density and Moisture .	11
	Stack Emission (Unit-2)			PM, SO _x , NO _x , CO ₂ , Hg, Oxygen, Flue gas Temp., Exit Velocity, Gas quantity (Volumetric flow rate)with density and Moisture .	11
2	Ambient Air Quality (24 Hrs Duration) - Shyamli guest house	Monthly	3	Sulphur Dioxide (SO ₂), Nitrogen Dioxide (NO ₂), PM- 2.5, PM-10, Ozone (O ₃), Lead (Pb), Carbon Monoxide (CO), Ammonia (NH ₃), Benzene (C ₆ H ₆), Benzo (a) Pyrene (BaP) – particulate phase, Arsenic (As), Nickel (Ni)	12
	Ambient Air Quality (24 Hrs Duration)- GCR building			Sulphur Dioxide (SO ₂), Nitrogen Dioxide (NO ₂), PM- 2.5, PM-10, Ozone (O ₃), Lead (Pb), Carbon Monoxide (CO), Ammonia (NH ₃), Benzene (C ₆ H ₆), Benzo (a) Pyrene (BaP) – particulate phase, Arsenic (As), Nickel (Ni)	12
	Ambient Air Quality (24 Hrs Duration) - DM plant			Sulphur Dioxide (SO ₂), Nitrogen Dioxide (NO ₂), PM- 2.5, PM-10, Ozone (O ₃), Lead (Pb), Carbon Monoxide (CO), Ammonia (NH ₃), Benzene (C ₆ H ₆), Benzo (a) Pyrene (BaP) – particulate phase, Arsenic (As), Nickel (Ni)	12
3	Physical/chemical parameters of Water/Effluent discharge	Monthly	7	Condensor Cooling (Unit-1) - pH, Temperature (Inlet),Free Available chlorine	3
				Condensor Cooling (Unit-2)- pH, Temperature (Inlet),Free Available chlorine	3
				Boiler Blowdown (Unit-1) - pH, TSS, Oil & Grease	3
				Boiler Blowdown (Unit-2) - pH, TSS, Oil & Grease	3
				DM plant Discharge- pH, TSS, BOD, COD, Total Hardness (as CaCO ₃), TDS, Temperature, Total Residual Chlorine	8
				Discharge channel - pH, Temperature (Outlet), free available Chlorine, Phosphate	4
				Ash Dam Effluent - pH, TSS, Oil & Grease, BOD, COD, TDS & DO	7
4	Metal/heavy metal Parameters of Water/Effluent discharge	Monthly	5	Boiler Blowdown Unit-1 - Copper & Iron	2
				Boiler Blowdown Unit-2 - Copper & Iron	2
				DM plant Discharge- Iron, Copper, Zinc & Chromium	4
				Discharge channel - Zinc & Chromium	2
				Ash Dam Effluent - Copper, Iron, Zinc & Chromium	4
5	Physical/chemical parameters of Surface Water	Quarterly	1	Dissolved Oxygen, Biochemical Oxygen Demand, Total Dissolved Solids, Total Suspended Solids, Colour, Conductivity, pH, Chlorides (as Cl),Sodium Absorption Ratio, Sulphates (as SO ₄), Nitrates (as NO ₃), Free Ammonia (as N), Fluorides (as F)	13
6	Physical/chemical parameters of Ground Water	Quarterly	1	Colour, Odour, Turbidity, Conductivity, pH, TDS, TSS, Calcium (as Ca) Fluoride (as F), Chloride (as Cl), Sulphate (as SO ₄), Nitrate (as NO ₃),Total Hardness (as CaCO ₃), Total Alkalinity (as CaCO ₃), Calcium Hardness (as CaCO ₃)	15
7	Metal/heavy metal Parameters of Water (surface water)	Quarterly	1	Boron (as B), Arsenic (as As), Iron (as Fe) , Lead (as Pb), Copper (as Cu), Zinc (as Zn)	6
8	Metal/heavy metal Parameters of Water (Ground water)	Quarterly	1	Magnesium (as Mg),	4
9	Preparation of Environmental statement of TTPS, Lalpania	Yearly	1	Environmental statement	1
10	Travelling Charges	Monthly	1	NA	12

Werner
Env. Consultant
(EMC)
13/04/2023

2021
13.04.2023
EE(1)