



GOVERNMENT OF TELANGANA
REGIONAL PUBLIC HEALTH LABORATORY, WARANGAL
 HANAMKONDA (KUDA Premises) - 506 001.
 Report of Physical, Chemical Analysis of Water &
 Chemical Analysis of Water for Construction Purpose



Sample from : Headmaster and Correspondent
 Collected by : Sub Father Colombo, School (F.M.)
 Collected on : 11/9/2026
 Received on : 11/9/2026
 Receipt No. : 0324
 Amount : 230.200
Dist - Jangaon

Lab Ref. No. :	1157	IS10500:2012
Address of Sources :	R.O. plant (Drinking) water	Acceptable limit Permissible limits in the absence of alternate source
Substance or Characteristic :		
Colour :	15	5
Odour :	Agreeable	Agreeable
Turbidity NTU :	-	1
*pH at °C :	6.9	6.5 - 8.5
Electrical conductivity (at 25° C Micro Mhos /cm) :	220	No relaxation
* Total Dissolved Solids (mg/Lt.) :	143	500
The following results are in mg/liter		
Phenolphthalein Alkalinity :	NIL	
Total Alkalinity (as CaCO ₃) :	18	200
Total hardness (as CaCO ₃) :	25	200
Calcium hardness (as CaCO ₃) :	13	
Magnesium hardness (as CaCO ₃) :	12	
Sulphate (as SO ₄ ²⁻) :	-	200
Nitrite (as NO ₂) :	NIL	
Nitrate (as NO ₃) :	-	10
*Chloride (as Cl) :	28	250
Fluoride (as F) :	0.02	1.0
Iron (as Fe) :	-	0.3
*To neutralize 100 ml of water sample using phenolphthalein indicator with 0.02N Na OH (in ml) :		Not more than 5 ml as per is 456 (2000) (Reaffirmed 2005)
*To neutralize 100 ml of water sample using Mixed indicator with 0.02N H ₂ SO ₄ (in ml) :		Not more than 25 ml as per is 456 (2000) (Reaffirmed 2005)

The Given water Sample is physico-chemically
 "SATISFACTORY" for Drinking purpose.

Signature
 Senior Analyst
 Regional Public Health Laboratory
 Hanumakonda.

Signature
 Civil Surgeon Bacteriologist,
 Regional Public Health Laboratory,
 Hanumakonda.

Annexure-C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHC/SC/20/2026

Date: 15-9-2026

It is certified that an inspection team headed by Dr. SRIVANI (Name of the Officers with designation) from Mo. PHC Ghanpur inspected the **FATHER COLOMBO SCHOOL** on 15-9-2026 of _____ (PHED Lab) certified that the **FATHER COLOMBO SCHOOL** has safe drinking water facilities for the students and members of Staff of the Institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central / State / U.T. Government.

This certificate is valid till 15.09.2027.

Signature with seal

Name :

Medical Officer

Designation:

UPHC Ghanpur (Str.)

Dist. Jangaon

Name & Address of the Office / Department

To

The H.M./Correspondent,
FATHER COLOMBO SCHOOL,
Station Ghanpur mandal
Jangaon Dist.
TELANGANA.

Note: The certificate is to be issued by authorized Officer / PHED Lab / localbodies.

Dr. SRIVANI