

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 298 | जल परीक्षण | 14

Dated: 27/6/2026

It is certified that an inspection team headed by Arunesh Sharma

(Name of Officers with designation) from U.P. Jal Nigam Etah PHED

inspected the S.D. Public School Shikshan Samsthan Dhumari Etah

(Name & Address of the school) on 24/6/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Etah/2026/24 dated 27/6/2026

of District Level Water analysis Lab (PHED Lab) certified that the

S.D. Public School Dhumari Etah (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 24/6/2027

Signature with Seal:

Name

: Arunesh Singh

Designation

: Executive Engineer

Name & Address of the Office / Department : Uttar

Pradesh Jal Nigam Etah

To
S.D. Public School Shikshan Samsthan Dhumari Etah
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



District Level Water Analysis Laboratory Uttar Pradesh Jal Nigam (Rural), Etah

Test Report

Report Issue Date	27/6/2026				
Letter No.		Date	27/6/2026		
Customer Name and Address	S.D.PUBLIC SCHOOL ETAH, VILLAGE -DHUMARI, BLOCK -JAITHARA				
Report No.	ETAH/14				
Sampling Method ISO 17614 (Part - 1):2021					
Sample Description:- Liquid transparent and colourless liquid received at ambient condition.					
Basic Details of Sample					
District	ETAH	Block	JAITHARA		
Gram Panchayat	DHUMARI	Village	JAITHARA		
Habitation	DHUMARI	Location	S.D. PUBLIC SCHOOL, VILLAGE -DHUMARI BLOCK -JAITHARA		
Water Source	SUMMER	Sample ID	ETAH/2026/24		
Sample Collector	KAMAL KUMAR	Date of sampling.	24/6/2026		
Depositor	KAMAL KUMAR	Receiving Date	25/6/2026		
Discipline Sample	Chemical	Analysis Start Date	25/6/2026		
Packaging Type	Glass Bottle	Analysis Completion Date	27/6/2026		
Group	Water	Quantity	1 Liter		
Latitude	27.516731	Longitude	79.002342		
Temperature (25± 3)°C	25°C	Humidity (50%± 15%)	46%		
Technical Data of Analysis					
SR. NO.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH @25°C	7.42	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022 (Electrometric Method)
2	Turbidity (NTU)	2.24	1.00	5.00	IS 3025 (Part 10): 2023 (Nephelometer Method)
3	TDS, mg/l	284.66	500	2000	IS 3025 (Part 16): 2023(Gravimetric Method)
4	Chloride (as Cl), mg/l	64.20	250	1000	IS 3025 (Part 32): 2025(Titration Method)
5	Total Alkalinity (as Na ₂ CO ₃), mg/l	92.66	200	600	IS 3025 (Part 23): 2023(Titration Method)
6	Total Hardness (as CaCO ₃), mg/l	120.00	200	600	IS 3025 (Part 21): 2023 (Titration Method)
7	Calcium (as Ca), mg/l	42.12	75	200	IS 3025 (Part 40): 2024 (Titration Method)
8	Magnesium (as Mg), mg/l	16.44	30	100	IS 3025 (Part 46): 2023
9	Sulphate (as SO ₄), mg/l	31.24	200	400	APHA 24 RD Ed 2023, 4500-SO ₄ (E. Turbidimetric Method)
10	Nitrate (as NO ₃), mg/l	2.16	45	No Relaxation	APHA 24 RD Ed 2023, 4500-NO ₃ (B. Ultraviolet Spectrophotometric Screening Method)
11	Fluoride (as F), mg/l	0.521	1.0	1.5	APHA 24 RD Ed 2023, 4500-F (C. Ion Selection Electrode Method)
12	Iron (as Fe), mg/l	0.01	1.0	No Relaxation	APHA 24 RD Ed 2023, 3500-Fe (B Phenanthroline Method)
13	Colour	6	5HU	15HU	APHA 24 RD Ed 2023, Colour Method (Platinum cobalt Visual Comparison):2017
14	Taste	Satisfactory	Qualitative	-	IS 3025 (Part 08): 2023
15	Odour	Agreeable	Qualitative	-	IS 3025 (Part 05): 2018
16	Free residual chlorine	0	0.2	1	IS 3025 (Part 26): 2021

.....End Of Report.....

Result Approved by

Quality Manager

Note:

1. Refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (In case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.
5. Water Sample is not collected by us.



District Level Water Analysis Laboratory, U.P. Jal Nigam Etah

Report No	Bacteriological Test/1/2026-2027	Date :	S.No 1	Page No	2	page 1/1
-----------	----------------------------------	--------	--------	---------	---	----------

Customer Details

Office Name and Address	S.D. PUBLIC SCHOOL ETAH, VILLAGE - DHUMARI, BLOCK - JAITHARA
Ref Letter No & Date	-

Basic details of sample

District	ETAH	Block	- JAITHARA
Gram Panchayat	- DHUMARI	Village	- DHUMARI
Habitation	- DHUMARI	Location	-- DHUMARI
Water Source	- SUMMAR	Sample No.	-14
Quality of Sample	- 1 LITTER	Date of S.C.	-24/6/2026
Receiving Date	-24/6/2026	S. Collector	- KAMAL KUMAR
Sample Depositer	- KAMAL KUMAR		
Analysis Start Date	-25/6/2026	Analysis Completion Date	27/6/2026

Environmental Condition

Temperature	22± 5 °C	Relative Humidity	Upto 70%
-------------	----------	-------------------	----------

Technical Data of Analysis

S.no.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2		3	4	5	6
1	Total Coliform	CFU/100 ml.	0.00	No Relaxation	No Relaxation	APHA 23rd Edition :2017,9222-B
2	E. Coli	CFU/100 ml.	0.00	No Relaxation	No Relaxation	APHA 23rd Edition :2017,9222-B

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 2 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Contaminated

Not Contaminated ✓

Authorized Signatory

(Microbiologist)