

Nexora AC

Frequently Asked Questions

This document provides answers to commonly asked questions regarding Nexora AC products, installation, maintenance, and usage.

Q: What is the ideal temperature setting for energy saving?

A: Set between 24-26 degrees Celsius for optimal energy efficiency.

Q: How often should I service my AC?

A: Every 3 months for optimal performance.

Q: Can I install Nexora AC myself?

A: Professional installation is strongly recommended. Self-installation voids the warranty.

Q: What stabilizer should I use?

A: Use a minimum 4KVA stabilizer for a 1.5 ton AC and 5KVA for a 2 ton AC.

Q: How do I clean the AC filter?

A: Remove the front panel, slide out the filter, wash with mild soap and water, allow it to dry completely before reinserting, and clean the filter every 2 weeks.

Q: What is the cooling capacity of Nexora AC units?

A: Nexora AC units are available in 1 ton, 1.5 ton, and 2 ton capacities, suitable for rooms between 100 and 250 square feet.

© Nexora AC. All rights reserved. This document is provided for informational purposes and represents a fictional company FAQ document.