


PSP(Unit 1)

- 1) Connected load
- 2) Maximum demand. / Peak load.
- 3) Demand factor = $\frac{\text{Max. demand}}{\text{Connected load}}$
- 4) Average load = $\frac{\text{Energy delivered}}{\text{Time taken}}$
- 5) Load factor = $\frac{\text{Average load}}{\text{Peak load}}$
 $= \frac{\text{Energy generated in given period}}{\text{Max. demand} \times \text{hours of operation in given period.}}$
- 6) Diversity factor = $\frac{\sum \text{individual max. demands of consumers}}{\text{Max. load on the sys.}}$
- 7) Capacity factor = $\frac{\text{Average annual load}}{\text{Plant capacity}}$
 $\text{Capacity factor} = \frac{\text{Rated plant capacity.}}{\text{factor}}$
- 8) Load Curve - graphical represent' of load in propo time sequence.
- 9) Load Duration Curve:



- 10) Reserve Capacity : 36 MW
 $+ 2 \text{ mw}$

Q. A residential consumer has 8 bulbs, 100W each, 2 fans, 60W each, 2 plug points of 100W each and his use of electricity is 12 midnight to 5am → 1 fan

5am to 7am → 2 fans & 1 plug.

7am to 9am → NIL

9am to 6pm → 2 Fans

6pm to midnight → 2 fans & 4 ^{but} ~~plug~~

Calculate i) connected load

ii) maximum demand

iii) Demand Factor

iv) Energy consumed in 24 hours.

v) Energy consumed in 24 hrs if all the devices ^{are used} all the day.

dol": 1) Connected load - 1120 W

2) Maximum demand - 520W \Rightarrow 120 + 400

3) Demand factor = $\frac{520}{1120} = 0.46$

4) $60 + 120 + 100 + 120 + 120 + 400 = 920 \text{ W.}$

5) 12 midnight to 5am $\rightarrow 60 \text{ W} \times 5 = 300 \text{ W}$

5am to 7am $\rightarrow 220 \text{ W} \times 2 = 440 \text{ W}$

7am to 9am $\rightarrow 0 = 0$

9am to 6pm $\rightarrow 120 \text{ W} \times 9 = 1080$

6pm to midnight $\rightarrow 520 \text{ W} \times 6 = 3120$

$\therefore = 4940 \text{ W.}$

5) $1120 \times 24 = 26880 \text{ W.}$

Q. A generating station supplies the following load to various consumers.

Industry - 450 MW

Commercial - 350 MW

Domestic Power - 110 MW

Domestic light - 80 MW

If the maximum demand on the stat' is 1000 MW and no. of MWh generated per yr = 150×10^6 . Determine

i) Diversity factor.

ii) Annual load factor.

Soln: i) Diversity factor = $\frac{1160 \text{ MW}}{1000 \text{ MW}}$

$$= 1.16$$

ii) Annual load factor = $\frac{1160}{1000 \times 80 \times 10^3} \times \frac{10^6}{1000} = \frac{1160}{800000} \times 10^3 = 0.0145 \times 10^3 = 0.0145 \times 1000 = 14.5\%$

Q. A generating stat' supplies the following loads 150 MW, 120 MW, 25 MW, 60 MW, 5 MW. The stat' has maximum demand of 220 MW and annual load factor of 42%. Calculate no. of units supplied annually.

i) Diversity factor.

ii) Demand factor.

Soln: i) $0.42 = \frac{\text{Energy generated}}{220 \times 8160}$

(No. of units) Energy generated = $9.45 \times 10^9 \text{ kWh} = 9.45 \times 10^6 \text{ MWh}$

ii) Diversity factor = $\frac{120}{220} = 0.55$

iii) Demand factor = $\frac{220}{450} = 0.49$

Q. Load on a power plant on a typical day is

Midnight - 6am - 10mw

6am - 10am - 30mw

10am - 6pm - 60mw


6pm - 10pm - 90mw

10pm - midnight - 20mw

Plot a daily load duration curve for this given power system. Also find average demand on the plant in 24 hours.

Avg. demand = $\frac{10 \times 6 + 30 \times 4 + 60 \times 8 + 90 \times 4 + 20 \times 2}{24}$

$$= \frac{1060}{24}$$
$$= 44.16$$



i) Diameter of stranded conductor

$$D = (2n-1)d$$

d = dia of single strand

n = no. of layers

ii) Total no. of strands

$$N = 3n^2 - 3n + 1$$

n = no. of layers

Q.	n	N	D
1	1	1	d
2	2	7	3d
3	3	19	5d
4	4	49	7d

iii) Spacing = $(0.75\sqrt{D} + \frac{V_{kv}^2}{20000})$ m
b/w cond's.

V_{kv} = voltage in kV

D = sag in m

iv) Length of the span:

Wooden poles - 50m


Steel tubular - 50 - 80m

RCC poles - 20 - 100m


Steel towers - 100 - 300m.

v) Sag calculation






Equal level span



Unequal level span.



$$S = \frac{WL^2}{8T}$$


m.

w = weight per unit length of conductor.

L = length of span.



T = Tension in cond^r.

Supports at unequal levels




$$d_1 = \frac{w x_1^2}{2T} \quad d_2 = \frac{w x_2^2}{2T}$$

*.) Effect of wind & ice loading



d : dia. of cond^r

t : thickness of ice cover



Total weight of cond^r per unit length

$$W_t = \sqrt{(W + w_i)^2 + (W_w)^2}$$

$W = W_t \cdot$ of cond^r p.u. length

= cond^r material density \times volume p.u. length.

$w_i =$ wt. of ice p.u. length

= density of ice \times volume of ice p.u. length.

= density of ice $\times \frac{\pi}{4} [(d+2t)^2 - d^2] \times 1$.

= density $\times \pi t [d + l]$.

$W_w =$ Wind force p.u. length.

= Wind pressure $\times [(d+2t) \times 1]$.

$$\tan \theta = \frac{W_w}{W + w_i}$$

$$\text{Sag.} = \frac{W_t L^2}{2T}$$

Here \rightarrow slant sag in a direction making angle θ .

i. Vertical sag. = $S \cos \theta$.

- Q. A 132 kV transmission line has following data. Weight of the conductor 680 kg/km. Length of span is 260m. Working tension, $T = 1550$ kg. Calculate the height above ground at which the conductor should be supported. Ground clearance req. is 10m. Assume both the supports are at same level.

$$\text{sag} = \frac{W_T L^2}{2T}$$


$$= \frac{0.688 \times (260)^2}{8 \times 1850}$$

$$\approx 3.7 \text{ m}$$

$$\text{height above ground} = 3.7 + 10 \\ \approx 13.7 \text{ m.}$$

4) Line Insulators

1. Porcelain - 60 kv/cm thickness
2. Glass - 140 kv/cm of thickness
3. Steatite - magnesium silicate



Q_1 = demand reactive power

Q_2 = supply "

$$Q_R = Q_1 - Q_2$$

$$Q_R = \left| \frac{V_s V_R}{X_L} \right| - \cos(\delta_1 - \delta_2) = \left| \frac{V_R^2}{X_L} \right|.$$

Assume $\delta_1 \neq \delta_2$, $\cos(\delta_1 - \delta_2)$ is negligible.

$$Q_R = \left| \frac{V_s V_R}{X_L} \right| = \left| \frac{V_R^2}{X_L} \right|$$

$$\therefore V_R^2 - V_s V_R + X_L Q_R = 0.$$

$$V_R = \frac{V_s \pm \sqrt{V_s^2 + X_L Q_R}}{2}$$

1 /

with -ve sign, solⁿ does not exist.

$$\therefore V_R = \frac{V_s}{2} + \sqrt{\frac{V_s^2 - f X_L Q_R}{2}}$$

Case-I:

$Q_R = 0, V_R = V_s \rightarrow \text{ideal.}$

Case-II:

$$Q_R > 0$$


i.e. $Q_1 > Q_2$.

i.e. $V_R < V_s$.

Case-III: $Q_R < 0 \quad V_R > V_s$

i.e. $Q_1 < Q_2$

f) Parallel operation of Alternator



3/2/22

Unit 2 : T.L. Parameters & Models.

X) Representation of T.L.

Generator



Motor




Two winding




Transformer

Δ


Three winding Trans.



C.T



P.T.



Circuit breaker (C.B.)





Isolator



Bus

Overhead Line/Cable/T.L.



Generator → emf in series with impedance.

Short line → series impedance.


Medium & long line → π ckt.

static load \rightarrow series. ξ react. in series

Motors \rightarrow equi. ckt.


Transformers \rightarrow imper. of windings.

Impedance diag.



a) Reactance Diag

1. Omit all series. ξ static load.
2. Omit magnetizing currents of trans. ^{neglect.}, capacitance.



Per unit = $\frac{\text{Actual Value}}{\text{Base Value.}}$

$\underbrace{\text{kVA, kV, current, impedance.}}_{\text{independent.}}$

Base Value $\rightarrow \text{kV}_B$.

P.U. value $\rightarrow \text{kV}_{\text{P.U.}}$

Base kVA = $(\text{kVA})_B / (\text{mVA})_B$.


Base kV = $(\text{kV})_B / (\text{MV})_B$.

Base current = $\frac{(\text{kVA})_B}{(\text{kV})_B}$.


Base impedance $\underline{Z}_B = \frac{\text{kV}_B \times 1000}{I_B} / \frac{(\text{kV})_B^2}{\text{MVA}_B}$.

P.U. impedance $\underline{Z}_{\text{pu}} = \frac{\underline{Z} \times (\text{kVA})_B}{(\text{kV})_B^2 \times 1000}$

when imp. is given in Ω .



G_1	30 MVA	10.5 kV	$X'' = 1.6 \Omega$
G_2	15 MVA	6.6 kV	$X'' = 1.2 \Omega$
G_3	25 MVA	6.6 kV	$X'' = 0.56 \Omega$
T_1	15 MVA	11/33 kV	$X'' = 15.2 \Omega/\text{ph.}$
T_2	15 MVA	33/6.6 kV	$X'' = 16 \Omega/\text{ph.}$
Load A	40 MW	11 kV	0.9 lag p.f.
Load B	40 MW	6.6 kV	0.85 lag p.f.
T.L.	$X'' = 20.5 \Omega/\text{ph.}$		



$$Z_{pu} = \frac{Z \times (MVA)_B}{(KV)_B^2}$$

Let $MVA_B = 30 \text{ MVA}$

For G_1 $Z_{pu} = \frac{1.6 \times 30}{(11)^2} = 0.396$.


For G_2 $Z_{pu} = \frac{1.2 \times 30}{(6.2)^2} = 0.936$.

For G_3 $Z_{pu} = \frac{0.66 \times 30}{(6.2)^2} = 0.437$.

For T.L. $Z_{pu} = \frac{20.5 \times 30}{(33)^2} = \frac{615}{1089} = 0.564$.

T_1 $Z_{pu} = \frac{15.2 \times 30}{(33)^2} = \frac{456}{1089} = 0.418$

T_2 $Z_{pu} = \frac{16 \times 30}{(33)^2} = 0.440$.



$G_1 = 30000 \text{ kVA}, 13.8 \text{ kV}, x = 15\%$

$M_1 = 20000 \text{ kVA}, 12.5 \text{ kV}, x = 20\%$

$M_2 = 10000 \text{ kVA}, 12.5 \text{ kV}, x = 20\%$

$T_1, T_2 = 38000 \text{ kVA}, x = 10\%$

$T_L = 80 \Omega$

Assuming base (kVA_B) = 30000

$$(\text{kV})_B = 13.8$$

$$\text{Z}_{\text{pu}} \text{ (new)} = \text{Z}_{\text{pu}} \text{ (old)} \times \frac{\text{MVA}_B \text{ (new)}}{\text{MVA}_B \text{ (old)}} \times \frac{\text{kV}_B \text{ (old)}}{\text{kV}_B \text{ (new)}}$$

$$\text{New kV}_B \text{ for T.L.} = 13.8 \times \frac{115}{13.2} = 120 \text{ kV}$$

$$\text{New kV}_B \text{ for Motor} = 120 \times \frac{13.2}{115} = 13.8 \text{ kV.}$$

New reactances,

$$G_1 = 0.15$$

$$M_1 = 0.2 \times \frac{30000}{20000} \times \frac{(12.5)^2}{(13.8)^2}$$

$$= \frac{937500}{3,808,800}$$

$$= 0.246.$$

$$M_2 = 0.2 \times \frac{30000}{10000} \times \frac{(12.5)^2}{(13.8)^2}$$

$$= \frac{93.75}{190.44}$$

$$= 0.492.$$


$$T_L = 80 \times \frac{30000}{(13.8)^2 \times 1000}$$

$$= 0.167 \text{ p.u.}$$

$$T_1 = 0.1 \times \frac{30000}{25000} \times \frac{(13.2)^2}{(13.8)^2}$$

$$= \frac{522.72}{6665.4} = 0.0784 \text{ p.u.}$$

$$T_2 = 0.0784 \text{ p.u.}$$



Q.



Gen - 40 MVA, 25 kV, 20%.

M - 50 MVA, 11 kV, 30%.

T₁ - 40 MVA, 33/220 kV 18%.

T₂ - 30 MVA, 220/11 kV 15%.

T.L. = 50 Ω

Use - (MVA)_B = 100 MVA, (kV)_B = 220 kV at T.L.

Soln: New kV_B at G: $G_1 = \frac{33}{220} = \frac{G}{220}$

$$G = \frac{33 \times 220}{220} = 33 \text{ kV}$$

New kV_B at M = $\frac{220}{11} = \frac{220}{m}$

$$= \frac{11 \times 220}{220} = 11 \text{ kV.}$$

New reactances

$$G = 0.2 \times \frac{100}{40} \times \frac{(25)^2}{(33)^2}$$


$$= \frac{12500}{45860} = 0.286$$

$$M = 0.3 \times \frac{100 \times (11)^2}{50} = 100 \times 0.6,$$

$$T_1 = 0.15 \times \frac{100 \times (33)^2}{40} = 0.375$$

$$T_2 = 0.18 \times \frac{100 \times (11)^2}{30} = 0.5$$

$$T.L. = 50 \times \frac{100}{(220)^2} = 0.103$$



$G_1 - 25 \text{ kV, } 100 \text{ MVA, } x = 9\%$

$G_2 - \text{---, ---}$

$T_1 - 25/220 \text{ kV, } 90 \text{ MVA, } x = 12\%$

$T_2 - 220/25 \text{ kV, } 90 \text{ MVA, } x = 12\%$

$T.L. - 220 \text{ kV, } x = 150 \Omega$

Base kV $\rightarrow 25 \text{ kV}$ at G_1 , MVA base = 200.

Q1: New KV_B at $G_1 = \frac{25}{220} = \frac{G_1}{220}$

$6 \text{ KV}_B \text{ at } (G_1) = 25 \text{ kV}$

New KV_B at $G_2 = \frac{220}{25} = \frac{220}{G_2}$

$KV_B (G_2) = 25 \text{ kV}$

New reactances

$$G_1 = 0.09 \times \frac{200}{100} \times \frac{(25)^2}{(25)^2}$$

$$G_1 = 0.09 \times 2.00 \times 0.18$$

$$G_2 = 0.9 \times \frac{200}{100} \times \frac{(25)^2}{(25)^2}$$

$$G_2 = 1.8 \text{ to } 0.18$$



$$T_1 = 0.12 \times \frac{200}{90} \times \left(\frac{25}{25}\right)^2$$

$$T_1 = 0.264 \text{ p.u.}$$

$$T_2 = 0.264 \text{ p.u.}$$

$$T.L. = 150 \times \frac{200}{(220)^2}$$

$$T.L. = 400 \text{ } 0.615 \text{ p.u.}$$



$$G_1 = 30 \text{ MVA} \quad 10.5 \text{ kV} \quad X = 0.435 \text{ p.u.}$$

$$G_2 = 15 \text{ MVA} \quad 6.6 \text{ kV} \quad X = 0.413 \text{ p.u.}$$

$$G_3 = 25 \text{ MVA} \quad 6.6 \text{ kV} \quad X = 0.3214 \text{ p.u.}$$

$$T_1 = 15 \text{ MVA} \quad 11/33 \text{ kV} \quad X = 0.209 \text{ p.u.}$$

$$T_2 = 15 \text{ MVA} \quad 33/6.6 \text{ kV} \quad X = 0.220$$

$$\text{Load A} = 10 \text{ MW} \quad 11 \text{ kV} \quad 0.9 \text{ p.f. lag.}$$

$$\text{Load B} = 10 \text{ MW} \quad 6.6 \text{ kV} \quad 0.85 \text{ p.f. lag.}$$

$$T.L. = 20.5 \Omega/\text{ph.}$$

$$\text{Base kV} = 11 \text{ kV} \quad \text{at } G_1 \text{ MVA}_B = 30 \text{ MVA.}$$

$$\text{New KV}_B \text{ for } G_1 = \frac{11}{33} = \frac{G_1}{33}$$

$$G_1 = 11 \text{ kV}$$

$$\text{New KV}_B \text{ for } G_2 = \frac{33}{6.2} = \frac{G_2}{6.2} \cdot \frac{33}{G_2}$$

$$G_2 = 6.2 \text{ kV}$$

$$G_3 = 6.2 \text{ kV}$$

New reactances

$$G_1 = 0.435 \times \frac{30}{30} \times \frac{(10.5)^2}{(11)^2}$$

$$G_1 = 0.396$$

$$G_2 = 0.413 \times \frac{30}{15} \times \frac{(6.6)^2}{(6.2)^2}$$

$$G_2 = 0.938$$

$$G_3 = 0.3214 \times \frac{30}{25} \times \frac{(6.6)^2}{(6.2)^2}$$

$$G_3 = 0.437$$

$$T_1 = 0.209 \times \frac{30}{15} \times \frac{(11)^2}{(11)^2}$$

$$= 0.418$$

$$T_2 = 0.220 \times \frac{30}{15} \times \frac{(6.2)^2}{(6.2)^2}$$

$$= 0.440$$

$$T.L. = 20.5 \times \frac{30}{(11)^2}$$

$$= 0.564$$

f) Transmission line Parameters.

Inductance (L) - Henry.

$$e = -L \frac{di}{dt}$$

$$L = \frac{N \Phi}{I}$$

Vltg. is induced due to change in flux linkage.

$$e = \frac{d\Phi}{dt} \text{ Volts}$$

Φ - flux linkage (wb-turns).

$$e = \frac{d\Phi}{di} \cdot \frac{di}{dt}$$

$$= L \frac{di}{dt} \quad L \rightarrow \text{inductance} = \frac{d\Phi}{di}$$

$$L = \frac{\Phi}{i} = \text{const.} \quad \text{- In linear det.}$$

Alternating Ckt:

$$\lambda = LI$$

$\lambda \rightarrow$ some value of flux linkage

$I \rightarrow$ Rms current.

$$L = \frac{\lambda}{I}$$

g) Partial flux linkage:

Inductance of cond' due to internal flux.

$$L = L_{\text{int}} + L_{\text{ext}}$$

$$\text{Mag. field strength } \pm H = \frac{I}{2\pi R} \text{ A/m.} \quad \text{--- (1)}$$

$$\text{Flux density } B = \mu H \text{ wb/m}^2 (\text{T}).$$

$$\text{Mc Muller, } \mu_0 = 4\pi \times 10^{-7}$$

$$B = \mu H \quad \text{--- (2)}$$

$$\text{Flux } \phi = B \cdot A \cos \theta \quad \text{--- (3)}$$


$B \rightarrow$ flux density

$A \rightarrow$ surface area. through which flux lines are passing.

$\theta \rightarrow$ angle which normal of that surface makes with flux lines.

$$\lambda = N\phi \rightarrow \text{flux linkage.} \quad \text{--- (4)}$$

$$L = \frac{\lambda}{I} \quad \text{--- (5)}$$



Let $r \rightarrow$ radius of cond^r conducting with scattering current I far away from cond^r under consideration.

Consider, section of radius y with thickness dy .

$ds \rightarrow$ small length in the section.

$h_y \rightarrow$ mag. field intensity at small section.

let current in section dy is I_y which is fraction of total current I .

$$h_y = \frac{I_y}{2\pi r y} \quad \text{--- (6)}$$

current is directly prop. to c.s. area.

$$\frac{I_y}{I} = \frac{\pi y^2}{\pi r^2}$$

$$I_y = \frac{y^2}{r^2} \cdot I \quad \text{--- (7)}$$

Substitute (7) in (6).

$$h_y = \frac{y^2}{r^2} \cdot I \cdot \frac{1}{2\pi y}$$

$$= \frac{y I}{2\pi r^2} \quad \text{--- (8)}$$

Mag. field density for section

$$B_y = \mu H_y$$

$$= \frac{\mu \cdot y \cdot I}{2\pi r^2} \text{ wb/m}^2 \quad \text{--- (9)}$$

$$\therefore \text{flux}, d\Phi = B_y \cdot dy \text{ wb/m.}$$

$$= \frac{\mu \cdot y \cdot I \cdot dy}{2\pi r^2} \text{ wb/m} \quad \text{--- (10)}$$

Flux linkage $d\lambda$ per m,

product of flux & fraction of current
fraction of current $I_y = \frac{\pi y^2}{\pi r^2}$.

$$\therefore d\lambda = \frac{y^2}{r^2} \cdot d\Phi.$$

$$d\lambda = \frac{\mu I y^3}{2\pi r^4} \cdot dy \quad \text{--- (11).}$$

\therefore Flux linkages for whole cond',

of radius r ,

$$\lambda_{int} = \int_0^r \frac{\mu I y^3}{2\pi r^4} dy$$

$$= \frac{\mu I}{8\pi} \quad \text{--- (12)}$$

$$\mu = \mu_0 \mu_r$$

$$\lambda_{int} = \frac{\mu_0 \mu_r I}{8\pi}$$


For cond' material $\mu_r = 1$

$$\therefore \lambda_{int} = 0.8 I \times 10^{-7} \text{ Wb-T/m} \quad \text{--- (13)}$$

$$\therefore L_{int} = \frac{\lambda_{int}}{I}$$

$$L_{int} = \frac{1 \times 10^{-7}}{2} + 1/\text{m} \quad \text{--- (14).}$$

Q) Flux linkages due to flux betⁿ 2 points external to cond?



Let R₁ & R₂ are 2 points external to cond' at dist.

R₁ & R₂ resp.

Consider a small section at dist. y with thickness dy.

Mag. field intensity at dist. y,

$$H_y = \frac{I}{2\pi y} \quad \text{--- (1)}$$

i.e. Flux db in the tubular element of thickness dy,

$$d\phi = \frac{\mu I}{2\pi y} dy \text{ wb/m.} \quad \text{--- (2)}$$

flux linkages,

$$d\lambda = 1 \times d\phi \quad \text{--- (3)}$$

for all the current I is linking.

i.e. Total flux linkages due to flux betⁿ points P₁ & P₂,

$$\therefore \lambda_{12} = \int_{R_1}^{R_2} \frac{\mu I}{2\pi y} dy$$

$$= \frac{\mu I}{2\pi} \ln\left(\frac{R_2}{R_1}\right)$$

$$\because \mu_0 = 1, \mu_0 = 4\pi \times 10^{-7}$$

$$\therefore \lambda = 2\pi \times 10^{-7} \cdot I \cdot \ln\left(\frac{R_2}{R_1}\right) \text{ wb.T/m.} \quad \text{--- (4)}$$

i.e. Inductance betⁿ R₁ & R₂,

$$L_{12} = \frac{\lambda_{12}}{I}$$

$$L_2 = 2 \times 10^{-7} \ln \left(\frac{D_2}{D_1} \right) \text{ H/m} - \textcircled{5}$$

Let external point is at dist. D,

$$\therefore \lambda_{\text{ext}} = 2 \times 10^{-7} I \cdot \ln \left(\frac{D}{x} \right) - \textcircled{6}$$

\therefore Total flux linkages,

$$\lambda = \lambda_{\text{int}} + \lambda_{\text{ext}}$$

$$= \frac{\pi}{2} \times 10^{-7} + \left(2 \times 10^{-7} \ln \frac{D}{x} \right)$$

$$\lambda = 2 \times 10^{-7} \cdot I \left(\frac{1}{2} + \ln \left(\frac{D}{x} \right) \right).$$

$$= 2 \times 10^{-7} I \cdot \ln \left(\frac{D}{x \sqrt{2}} \right).$$


$$\text{Let } x' = x \cdot e^{1/4} = 0.7788 x.$$

$$\therefore \lambda = 2 \times 10^{-7} I \cdot \ln \left(\frac{D}{x'} \right) \text{ Wb-T/m.} - \textcircled{7}$$

\therefore Inductance due to flux upto external point

$$L = 2 \times 10^{-7} \ln \left(\frac{D}{x'} \right) \text{ H/m.} - \textcircled{8}$$

i) Inductance of 1 ph. 2 wire line.



In a single ph. line

$$I_1 + I_2 = 0$$

$$I_1 = -I_2$$

Flux linkages of ckt due to Σ

$$\Lambda_1 = 2 \times 10^7 I_1 \ln\left(\frac{D}{s_1}\right).$$

\therefore Inductance due to Σ

$$L = 2 \times 10^7 \ln\left(\frac{D}{s_1}\right).$$

Similarly, $L_2 = 2 \times 10^7 \ln\left(\frac{D}{s_2}\right)$.


\therefore Total inductance of ckt; using superposition principle

$$L = L_1 + L_2 \\ = 2 \times 10^7 \ln\left(\frac{D^2}{s_1 s_2}\right) \text{ H/m.}$$

$$\text{If } s_1' = s_2' = s_1$$

$$= 4 \times 10^7 \ln\left(\frac{D}{s_1}\right) \text{ H/m.}$$

* Flux linkages of one cond^r in a group (bunched cond^r)



To derive,
Flux linkages of i^{th} cond.
Considering the flux upto point
P only.

Let $1, 2, 3, \dots, i, j, \dots, n$ are the cond^rs in group.
Each cond^r is of round shape.

Each cond^r carries current $I_1, I_2, \dots, I_i, \dots, I_n$ resp.

$$\therefore I_1 + I_2 + \dots + I_i + I_j + \dots + I_n = 0.$$

$$I_n = -(I_1 + I_2 + \dots + I_i + I_j + \dots + I_{n-1}).$$

* Flux linkages of i th cond' due to its own current.

$$\lambda_{ii} = 2 \times 10^7 I_i \ln \left(\frac{D_i}{\sigma_i} \right). \quad \text{--- (1)}$$

Similarly, flux linkages in i due to current in j th cond'.

$$\lambda_{ij} = 2 \times 10^7 I_j \ln \left(\frac{D_j}{D_{ij}} \right). \quad \text{--- (2)}$$

From eqn (1) & repeated use of (2), total flux linkages of i th cond',

$$\begin{aligned} \lambda_i &= \lambda_{i1} + \lambda_{i2} + \dots + \lambda_{ij} + \dots + \lambda_{in} \\ &= 2 \times 10^7 \left[I_1 \ln \left(\frac{D_1}{D_{i1}} \right) + I_2 \ln \left(\frac{D_2}{D_{i2}} \right) + I_i \ln \frac{D_i}{\sigma_i} \right. \\ &\quad \left. + \dots \ln \ln \left(\frac{D_n}{D_{in}} \right) \right] \quad \text{--- (3)} \end{aligned}$$

$$\begin{aligned} \lambda_i &= 2 \times 10^7 \left[\left(I_1 \ln \left(\frac{1}{D_{i1}} \right) + I_2 \ln \left(\frac{1}{D_{i2}} \right) + \dots \right. \right. \\ &\quad \left. I_i \ln \left(\frac{1}{\sigma_i} \right) + \dots \ln \ln \left(\frac{1}{D_{in}} \right) \right. \\ &\quad \left. + \left(I_1 \ln (D_1) + I_2 \ln (D_2) + I_i \ln (D_i) + \dots \right. \right. \\ &\quad \left. \left. \ln \ln (D_n) \right) \right] \quad \text{--- (4)} \end{aligned}$$

using, $I_n = -(I_1 + I_2 + \dots + I_{n-1})$. in n th term of eqn (4).

$$\begin{aligned} \lambda_i &= 2 \times 10^7 \left[\left(I_1 \ln \left(\frac{1}{D_{i1}} \right) + I_2 \ln \left(\frac{1}{D_{i2}} \right) + \dots + I_i \ln \left(\frac{1}{\sigma_i} \right) + \right. \right. \\ &\quad \left. \left. \ln \ln \left(\frac{1}{D_{in}} \right) \right) \right. \\ &\quad \left. + \left(I_1 \ln \left(\frac{D_1}{D_n} \right) + I_2 \ln \left(\frac{D_2}{D_n} \right) + \dots + I_i \ln \left(\frac{D_i}{D_n} \right) + \dots \right. \right. \\ &\quad \left. \left. \dots \right) \right] \end{aligned}$$

$$[I_{n-1} \ln \left(\frac{D_{n-1}}{D_n} \right) \dots] \rightarrow ⑤$$


To find total flux linkages,
let point P move to infinity
terms like $\ln \left(\frac{D_1}{D_n} \right) = \ln(1) = 0$

For getting symmetry,

$$\text{let } g_{ii}' = D_{ii}$$

$$\therefore \lambda_i = \alpha \times 10^7 \left(I_1 \ln \left(\frac{1}{D_{11}} \right) + I_2 \ln \left(\frac{1}{D_{12}} \right) + \dots + I_i \ln \left(\frac{1}{D_{ii}} \right) + \dots + I_n \ln \left(\frac{1}{D_{in}} \right) \right)$$

x) Inductance of composite cond' lines.



cond' A \rightarrow n no. of filaments., I.

cond' B \rightarrow m' no. of filaments., -I.

Current I & -I is equally divided in n & m' no. of filaments resp.

Current in each filament (A) $\rightarrow I/n$.

Current in each filament (B) $\rightarrow -I/m'$.

Applying eqⁿ of group of cond's to filament i of cond' A, to get its flux linkages

$$\lambda_i = 2 \times 10^7 \frac{I}{n} \left(\ln \left(\frac{1}{D_{i1}} \right) + \ln \frac{1}{D_{i2}} + \dots + \ln \frac{1}{D_{ii}} + \dots + \ln \frac{1}{D_{in}} \right)$$

$$2 \times 10^7 \frac{I}{n} \left(\ln \frac{1}{D_{i1}'} + \ln \frac{1}{D_{i2}'} + \dots + \ln \frac{1}{D_{in}'} \right) - \textcircled{1}$$

$$\therefore \lambda_i = 2 \times 10^7 I \cdot \ln \left[\frac{(D_{i1}' \cdot D_{i2}' \cdots D_{in}')^{1/m'}}{(D_{i1} \cdot D_{i2} \cdots D_{in})^{1/n}} \right] - \textcircled{2}$$

∴ Inductance of filament i,

$$L_i = \frac{\lambda_i}{I/n} = 2 \times 10^7 \ln \left[\frac{(D_{i1}' \cdot D_{i2}' \cdots D_{in}')^{1/m'}}{(D_{i1} \cdot D_{i2} \cdots D_{in})^{1/n}} \right] - \textcircled{3}$$

∴ Avg. inductance of filaments in cond' A

$$L_{avg} = \frac{L_1 + L_2 + \dots + L_n}{n} - \textcircled{4}$$

∴ Inductance of cond' A is Y_n times its avg. inductance

$$L_A = \frac{L_{avg}}{n} = \frac{L_1 + L_2 + \dots + L_n}{n^2} - \textcircled{5}$$

∴ To get L_A , use eqⁿ $\textcircled{3}$ in $\textcircled{5}$,

$$L_A = 2 \times 10^7 \left[\frac{\left[(D_{i1}' \cdot D_{i2}' \cdots D_{in}') \cdots (D_{i1}' \cdot D_{i2}' \cdots D_{in}') \right]}{\left[(D_{n1}' \cdot D_{n2}' \cdots D_{nm}') \right]} \right] \frac{1/m}{\left[(D_{i1} \cdot D_{i2} \cdots D_{in}) \cdots (D_{i1} \cdot D_{i2} \cdots D_{in}) \right]^{1/n}} \cdots \frac{1}{(D_{n1} \cdot D_{n2} \cdots D_{nm})}$$

A/m.


$N_r \rightarrow$ Mutual Geometric Mean distance, (D_m).

$D' \rightarrow$ Self GMD. (Geometric mean radius) (D_{SA}).

$$L_A = 2 \times 10^7 \ln \left(\frac{D_m}{D_{SA}} \right) + 1/m.$$

$$L_1 = 2 \times 10^7 \ln \left(\frac{D}{\sigma_1} \right).$$

f)



$$I_a + I_b + I_c = 0$$

$$I_b + I_c = -I_a.$$

Symm./ Equilateral


Flux linkages of cond^r a.

$$\lambda_a = 2 \times 10^7 \left[I_a \ln \frac{1}{\sigma_1} + I_b \ln \frac{1}{D} + I_c \ln \frac{1}{D} \right]$$

$$\lambda_a = 2 \times 10^7 \left[I_a \ln \frac{1}{\sigma_1} - I_a \ln \frac{1}{D} \right]$$

$$\lambda_a = 2 \times 10^7 I_a \left(\frac{D}{\sigma_1} \right) \text{ cels}$$

$$L_a = 2 \times 10^7 \ln \left(\frac{D}{\sigma_1} \right) + 1/m.$$



Transposition of cond^rs.

At position 1, the flux linkages of a.

$$\lambda_{a1} = 2 \times 10^7 \left[I_a \ln \frac{1}{x'_a} + I_b \ln \frac{1}{D_{12}} + I_c \ln \frac{1}{D_{13}} \right]$$

At position 2,

$$\lambda_{a2} = 2 \times 10^7 \left[I_a \ln \frac{1}{x'_a} + I_b \ln \frac{1}{D_{23}} + I_c \ln \frac{1}{D_{12}} \right]$$

At position 3,

$$\lambda_{a3} = 2 \times 10^7 \left[I_a \ln \frac{1}{x'_a} + I_b \ln \frac{1}{D_3} + I_c \ln \frac{1}{D_{23}} \right]$$

Avg. flux linkages of cond' a,

$$\lambda_a = \underline{\lambda_{a1} + \lambda_{a2} + \lambda_{a3}}$$

3

$$= 2 \times 10^7 \left[I_a \ln \frac{1}{x'_a} + I_b \ln \frac{1}{(D_{12} \cdot D_{23} \cdot D_{31})^{1/3}} + I_c \ln \frac{1}{(D_{12} \cdot D_{23} \cdot D_{31})^{1/3}} \right]$$

$$I_b + I_c = -I_a$$

$$\lambda_a = 2 \times 10^7 I_a \ln \left[\frac{(D_{12} \cdot D_{23} \cdot D_{31})^{1/3}}{x'_a} \right]$$

$$\text{Let } D_{eq} = (D_{12} \cdot D_{23} \cdot D_{31})^{1/3}$$

$$\therefore \lambda_a = 2 \times 10^7 I_a \ln \frac{D_{eq}}{x'_a}$$

∴ Inductance of a

$$\boxed{L_a = 2 \times 10^7 \ln \frac{D_{eq}}{x'_a}}$$

Q. A 8ϕ , transmission line has cond' diameter of 1.8 cm each, cond'rs being spaced as 4cm, 6cm, 9cm. The loads are balanced and the line is transposed. Find inductance of the line per phase per km.

Soln:

$$a_d = 0.9 \text{ cm}$$

$$r_d = 0.70 \text{ cm}$$

$$D_{eq} = (4 \times 6 \times 9)^{\frac{1}{3}}$$

$$= 5.89 \text{ cm}$$

$$L_a = 2 \times 10^7 \ln \frac{D_{eq}}{a_d}$$

$$= 2 \times 10^7 \ln \frac{5.89}{0.70}$$

$$= 2 \times 10^7 \times 2.12$$

$$= 4.25 \times 10^7 \text{ H/cm}$$

$$= 4.25 \times 10^4 \text{ H/km.}$$

Q. A 8ϕ 80 km long transmission line has conductance of 1cm diameter spaced at the corners of equilateral triangle of 100cm sides. Find inductance per phase for the entire system.

Soln:

$$g_d = 0.5 \text{ cm}$$

$$r_d = 0.5 \times 0.7788$$

$$= 0.38 \text{ cm}$$

$$D_{eq} = (100^3)^{\frac{1}{3}}$$

$$= 100 \text{ cm}$$

$$L_a = 2 \times 10^7 \ln \frac{100}{0.38}$$

$$= 100 \times 10^7 \times 80 = 891.6 \times 10^4$$

$$= 891.6 \times 10^4 = 0.089 \text{ H/km.}$$

Q. Calculate loop inductance per km of a single phase transmission comprising of 2 parallel cond^{ts} 1 m apart and 1.25 cm diameter. Also calculate reactance of the transmission line if the frequency is 50 Hz.

Solⁿ:

$$a = 0.62 \text{ cm}$$

$$a' = 0.48 \text{ cm}$$

$$D = 10^{\frac{82}{2}} \text{ cm}$$

$$L = 4\pi \times 2 \times 2 \times 10^7 \ln \left(\frac{100}{0.48} \right)$$

$$= 20130 \times 40 \quad 21.3 \times 10^7 \text{ H/cm.}$$

$$= 21.3 \times 10^4 \text{ H/km} = 2.13 \times 10^3 \text{ H/km}$$

$$X_L = \frac{2\pi f L}{2\pi R^2}$$

$$= 2\pi \times 10 \times 50 \times 2.13 \times 10^3$$

$$= 0.669 \text{ Nf/km.}$$

* Resistance of T.L.

AC

$$R = \frac{\text{Power loss in T.L.}}{I^2}$$

DC

$$R = \frac{P_l}{A}$$


* Skin effect:

→ increase in power loss.

ACSR

* Proximity effect


*.) Capacitance of a wire line.




Capacitance of each line to the neutral

$$C_n = \frac{0.0242 \text{ } \mu\text{F}/\text{km}}{\log(D/r)}$$

*) Capacitance of 3 ph. line with equilateral spacing.



$$C_n = \frac{0.0242 \text{ } \mu\text{F}/\text{km}}{\log(D/r)}$$



$$C_n = \frac{0.0242 \text{ } \mu\text{F}/\text{km}}{\log(D_{eq}/r)}$$

$$D_{eq} = (D_{12}, D_{23}, D_{31})^{y_3}.$$

- Q. Calculate capacitance to neutral per km of a single phase line composed of two single stranded conductors having radius 0.328 cm and placed 3 m apart.

Soln:

$$C_n = \frac{0.0242}{\log(\frac{D}{d})} \text{ uF/km.}$$

$$= \frac{0.0242}{\log(\frac{300}{0.328})}$$

$$= \frac{0.0242}{2.96} = 8.17 \times 10^{-3} \text{ uF/km.}$$

- Q. A 3Ø 50Hz transmission line has flat horizontal spacing with 3.5 m b/w adjacent cond's. The conductor has diameter of 1.05 cm. The vltg. of the line is 110kV. Find capacitance to neutral and the charging current per km of line.

Soln:

$$d = 0.525 \text{ cm}$$

~~$$C = \frac{0.0242}{\log(\frac{350}{0.525})}$$~~

~~$$= \frac{0.0242}{2.82}$$~~

~~$$= 8.5 \times 10^{-3} \text{ uF/km.}$$~~

~~$$X_C = \frac{1}{2\pi f C}$$~~

~~$$= \frac{1}{2\pi \cdot 50 \cdot 8.5 \times 10^{-3}}$$~~

$$= 0.37$$

$$I = \frac{M \times V}{R^2}$$

$$D_{eq} = (3.5 \times 3.5 \times 7)^{1/3}$$

$$= 4.34 = 434$$

$$C = \frac{0.0242}{\log(\frac{434}{0.525})}$$

$$= \frac{0.0242}{2.96 - 2.97}$$

$$= 8.3 \times 10^{-3} \text{ uF/km}$$

$$X_C = \frac{1}{2\pi f C}$$

$$= \frac{1}{2\pi \cdot 50 \cdot 8.3 \times 10^{-3}}$$

$$= 30.28 \times 10^3$$

$$V_{ph} = 110/\sqrt{3} = 63.9 \text{ V}$$

$$I = \frac{V_{ph}}{X_C}$$

$$= \frac{63.9}{3.8 \times 10^5}$$

$$= 0.16 \text{ A/km.}$$

T.L. Models:

Short T.L. : - length < 100 km.

V_{tg} < 20 kV.

$R_1 L_1 C$ Medium T.L. - length between 100 - 250 km.


V_{tg} - upto 100 kV.

$R_1 L_1 C$ distributed Long T.L. - length > 250 km


V_{tg} > 100 kV.

Medium T.L.:


Nominal π



Nominal T



Generalised ckt. const. A, B, C, D.




$$V_s = \bar{A}\bar{V}_R + \bar{B}\bar{I}_R$$

$$I_s = \bar{C}\bar{V}_R + \bar{D}\bar{I}_R$$

f) Imp points:

1. A, B, C, D are complex no.s.
2. A & D are dimensionless.
3. Units of B & C are ohms & mho resp.
4. For given transmission line, $\bar{A} = \bar{B}$.
5. $\bar{AB} - \bar{BC} = 1$

f) For a short T.L.:




$$I_s = I_R \Rightarrow I_s = 0V_R + I_R.$$

$$V_s = V_R + ZI_R$$

$$A=1, B=Z, C=0, D=1.$$

f) Nominal T ckt.



$$V_s = V_C + I_s \cdot \frac{Z}{2} \quad \text{--- ①}$$

$$V_C = V_R + I_R \cdot \frac{Z}{2} \quad \text{--- ②}$$

$$I_s = I_C + I_R \Rightarrow I_C = I_s - I_R.$$

$$I_C = V_C \cdot Y$$

$$= Y \left(V_R + I_R \cdot \frac{Z}{2} \right) \quad \text{--- ③}$$

$$I_s = I_R + Y \left(V_R + I_R \cdot \frac{Z}{2} \right).$$

$$I_S = Y \cdot V_R + \left(1 + \frac{YZ}{2} \right) I_R \quad \text{--- (4)}$$

$$C = Y \quad D = 1 + \frac{YZ}{2}$$

Put value of V_C in eqⁿ (1).


$$V_S = V_R + I_R \cdot \frac{Z}{2} + I_S \cdot \frac{Z}{2} \quad \text{--- (5)}$$

From eqⁿ (4), get value of I_S in (5)

$$V_S = \left(1 + \frac{YZ}{2} \right) V_R + \left(Z + \frac{YZ^2}{4} \right) I_R \quad \text{--- (6)}$$

$$D = A = 1 + \frac{YZ}{2} \quad B = Z + \frac{YZ^2}{4} \quad C = Y$$

X) Nominal Π ckt:



$$V_S = A V_R + B I_R$$

$$I_S = C V_R + D I_R$$

$$\begin{aligned} I_S &= I_L + I_{C2} \\ &= I_L + V_S \cdot \frac{Y}{2} \end{aligned} \quad \text{--- (1)}$$

$$\begin{aligned} I_L &= I_R + I_{C1} \\ &= I_R + V_R \cdot \frac{Y}{2} \end{aligned} \quad \text{--- (2)}$$


$$\begin{aligned} V_S &= V_R + I_L Z \\ &= V_R + (I_R + V_R \cdot \frac{Y}{2}) Z \\ &= V_R \left(1 + \frac{YZ}{2} \right) + I_R \cdot \frac{Z}{2} \end{aligned} \quad \text{--- (3)}$$

Put the value of I_L in eqn ①.

$$\begin{aligned} I_B &= I_L + \frac{V_b}{R_s} \cdot \frac{1}{2} \\ &= (I_B + V_R \cdot \frac{1}{2}) + V_R \cdot \frac{1}{2} \\ &= \underbrace{1 \left(1 + \frac{V_R}{R_s}\right)}_C V_R + \underbrace{\left(1 + \frac{V_R}{R_s}\right) I_B}_D. \end{aligned}$$

$$V_b = AV_p + BV_B$$

$$I_B = CV_p + DI_B$$



If R.E. is O.C.

$$V_b = A V_p \rightarrow B = \frac{V_b}{V_p} \quad I_B = 0.$$

$$I_B = CV_p \rightarrow C = I_B/V_p.$$

If R.E. is S.C.


$$\therefore V_B = 0.$$

$$V_b = BI_B$$

$$B = V_b/I_B \cdot R_s$$


$$I_B = DI_B$$

$$D = I_B/I_A$$



If $V_p = 1V$, calculate A, B, C, D.

soln:



$$-I_1 - 1(I_1 - I_2) = 0$$

$$-2I_2 - 2I_2 - 1(I_2 - I_1) = 0$$

$$-2I_1 + 2I_2 = 0$$

$$I_1 = 6I_2 = 0$$

$$I_1 = 0.04A \quad I_2 = 0.02$$

— / —

Put the value of I_L in eqⁿ ①.

$$I_S = I_L + V_s \cdot Y/2$$

$$= (I_R + V_R \cdot Y/2) + V_s \cdot Y/2$$

$$= Y \left(1 + \frac{Y^2}{4} \right) V_R + \left(1 + \frac{Y^2}{2} \right) I_R$$

C

D

$$V_s = A V_R + B I_R$$

$$I_S = C V_R + D I_R$$



If R.E. is O.C.

$$V_s = A V_R \rightarrow A = \frac{V_s}{V_R}, \quad I_R = 0.$$

$$I_S = C V_R \rightarrow C = I_S / V_R.$$

If R.E. is S.C.


$$\therefore V_R = 0.$$

$$V_s = B I_R$$

$$B = V_s / I_R \text{ S2.}$$


$$I_S = D I_R$$

$$D = I_S / I_R.$$



If $V_s = 1V$, calculate A, B, C, D.

soln:



$$-I_1 - 1(I_1 - I_2) + \text{#} = 0$$

$$-3I_2 - 2I_2 - 1(I_2 - I_1) = 0$$

$$-2I_1 + I_2 \text{#} = 0$$

$$I_1 - 6I_2 = 0.$$

$$I_1 = 0.84 \text{ A} \quad I_2 = 0.09$$

$$V_R = I_2 \times 2$$


$$= 0.18$$

$$I_1 = I_3$$

$$I_2 = I_R.$$

$$\Lambda = \frac{V_s}{V_R} = \frac{1}{0.18} = 5.55$$

$$C = \frac{I_2}{V_R} = \frac{0.05}{0.18} = 0.55 \times 10^{-3}$$



$$1 - I_1 - 1(I_1 - I_2) = 0$$

$$1 - 2T_1 + I_2 = 0 \quad \text{--- (1)}$$

$$-1(I_2 - I_1) - 3I_2 - 2(I_2 - I_3) = 0$$

$$-6I_2 + 2I_1 + 2I_3 = 0$$

$$I_1 - 6I_2 + 2I_3 = 0 \quad \text{--- (2)}$$

$$-2(I_3 - I_2) - 2I_3 = 0$$

$$-4I_3 + 2I_2 = 0 \quad \text{--- (3)}$$

$$I_1 = 0.55 \quad I_2 = 0.11 \quad I_3 = 0.055 \quad I_R = \frac{1}{18}$$

$$I_S = 0.55A \quad (\text{d}) \quad I_R = 0.055$$

$$B = \frac{V_s}{I_R} = \frac{1}{0.055} = 18.1$$

$$D = \frac{I_R}{I_R} = \frac{0.55}{0.055} = 10.$$

Q.2 110kV, 50Hz, 200 km long is open circ. at R.C.

$$R = 0.3 \Omega/km$$

$$X_L = 0.2 \Omega/km$$

$$Y = 0.067 \Omega^{-1}/km$$

Calculate A, B, C, D with nominal T n/w.

$$\text{Soln: } A = D = 1 + \frac{4Z}{2}$$

$$\begin{aligned} Z &= \sqrt{R^2 - X_L^2} \\ &= \sqrt{(0.3)^2 - (0.2)^2} \\ &= \sqrt{0.09 + 0.04} \\ &= \sqrt{0.13} \\ &= 0.36 \end{aligned}$$

$$\begin{aligned} A &= 1 + \frac{0.06 \times 10^4 \times 0.36}{2} \\ &= 1 + \frac{0.0216 \times 10^4}{2} \\ &= 1 + 0.0108 \times 10^4 \end{aligned}$$

$$A, D = 1.00$$

$$C = 0.06 \times 10^4 \text{ F/km}$$

$$\begin{aligned} B &= Z \left(1 + \frac{4Z}{f} \right) \\ &= 0.36 \left(1 + \frac{0.06 \times 10^4 \times 0.36}{f} \right) \end{aligned}$$

$$B = 0.36 \Omega$$

→ For TT connection.

$$V_s = 110V.$$

$$A = \frac{1+4Z}{2}$$

$$C = \frac{1}{4} \left(1 + \frac{4Z}{f} \right)$$

$$A = 1.00$$

$$= 0.06 \times 10^4 \left(1 + \frac{0.06 \times 10^4 \times 0.36}{f} \right)$$

$$B = I_R Z$$

$$I_R = 0$$

$$= 6 \times 10^6$$

$$V_R = 110V.$$

$$D = 1 \times 10^4 \text{ A/m}$$

Unit-3

4) Source Impedance (Z_s or Z_c)

$$Z_s = \sqrt{\frac{Z}{Y}}$$

Z = series impedance = $R + jX$

Y = shunt admittance = $G + jB$

$$Z = \sqrt{\frac{L}{C}}$$

Capacitive VAR = Inductive VAR

$$V \cdot I = V \cdot I$$

$$\frac{V \cdot V}{X_C} = I \cdot X_L \cdot I$$

$$\frac{V^2}{X_C} = I^2 X_L$$

$$\frac{V}{I} = \sqrt{X_L X_C}$$

$$Z_s = \sqrt{\frac{L}{C}}$$

(Source Impedance).

$Z_{oc}, Z_{sc} \rightarrow$ S.E. impedance at O.C & S.C (resp)

$$V_s = A V_R + B I_R$$

if R.F. is S.C.

$$I_s = C V_R + D I_R$$

$$\frac{V_s}{I_s} = \frac{B}{D} = Z_{sc}$$

if R.F. is O.C.

$$\frac{V_s}{I_s} = \frac{A}{C} = Z_{oc}$$

$$Z_{oc} \times Z_{sc} = \frac{A \times B}{C \times D}$$

$$Z_{oc} \times Z_{sc} = \frac{B}{C} = \frac{V}{Y}$$

$$\therefore Z_s = \sqrt{Z_{0.c.} Z_{S.c.}}$$

* A, B, C, D for Long T.L

$$\begin{bmatrix} V_s \\ I_s \end{bmatrix} = \begin{bmatrix} \cosh \gamma l & Z_s \sinh \gamma l \\ \frac{1}{Z_s \sinh \gamma l} & \cosh \gamma l \end{bmatrix} \begin{bmatrix} V_R \\ I_R \end{bmatrix}$$

$$A = \cosh \gamma l = BD \quad \text{where } \gamma = \sqrt{Y/Z}$$

$$B = Z_s \sinh \gamma l \quad Z_s = \sqrt{\frac{Z}{Y}}$$

$$C = \frac{1}{Z_s \sinh \gamma l} \quad l = \text{length.}$$


* Surge Impedance load \rightarrow power delivered to a load value of Z_s .

* Power transmitted under S.I.L cond'n


$$P_R = \frac{V_R^2}{Z_s}$$

P_R = surge impedance loading.

* Feranti Effect:



$$V_s = V_R + j\omega R + j\omega X_L$$



For nominal π ckt

$$V_s = \left(1 + \frac{Y_Z}{2}\right) V_R + Z \cdot I_R$$

at no load, $I_R = 0$

$$V_s = \left(1 + \frac{Y_Z}{2}\right) V_R$$

$$V_{R-dB} = V_s - V_R = V_R \left(1 + \frac{Y_Z}{2} - 1\right)$$

$$= \frac{Y_Z}{2} \cdot V_R$$

where $Z = R + jX_L$ if R is negligible

$$Y = j\omega C, \quad Z = j\omega L$$

$$V_s - V_R = \frac{1}{2} (j\omega L)(j\omega C) V_R$$

$$= -\frac{1}{2} \omega^2 LC V_R$$

$$V_s < V_R$$

*) Tuned Power lines

$$\begin{bmatrix} V_s \\ I_s \end{bmatrix} = \begin{bmatrix} \cosh \beta l & z_s \sinh \beta l \\ z_s \sinh \beta l & \cosh \beta l \end{bmatrix} \begin{bmatrix} V_R \\ I_R \end{bmatrix}$$

$R \approx$ negligible
 $G \approx$

$$\cosh \beta l = \cos j\omega l \sqrt{LC}$$

$$= \cos \omega l \sqrt{LC}$$

using $\cosh j\theta = \cos \theta$

$$\sinh \beta l = \sinh j\omega l \sqrt{LC} = j \sin \omega l \sqrt{LC}$$

using $\sinh j\theta = j \sin \theta$.

$$\begin{bmatrix} V_s \\ I_s \end{bmatrix} = \begin{bmatrix} \cos \omega l \sqrt{LC} & j z_s \sin \omega l \sqrt{LC} \\ \frac{1}{z_s} \sin \omega l \sqrt{LC} & \cos \omega l \sqrt{LC} \end{bmatrix} \begin{bmatrix} V_R \\ I_R \end{bmatrix}$$

to get, $|V_s| = |V_R|$ and $|I_s| = |I_R|$,

if $\omega l \sqrt{LC} = n\pi$, $n = 1, 2, 3, \dots$.

$$l = \frac{n\pi}{\omega \sqrt{LC}} = \frac{n\pi}{2\pi f \sqrt{LC}} = \frac{n}{2f \sqrt{LC}}$$


$$\therefore \frac{1}{\sqrt{LC}} \approx v \quad \text{velocity of light}$$

$$= 300000 \text{ km/s}$$

\therefore for 50Hz freq, to get tuned lines

$$l = 3000, 6000, \dots \text{ km.}$$

*) Power flow through T.L.



Let V_R is reference voltage
 V_S leads V_R by δ° .

Complex powers at SE & RE.

$$S_s = P_s + jQ_s = V_S \cdot I_B^*$$

$$S_R = P_R + jQ_R = V_R \cdot I_R^*$$

$$P_R = \frac{|V_S| |V_R| \sin \delta}{X}$$

$$Q_R = \frac{|V_R|}{X} (|V_S| - |V_R|)$$


$$= \frac{|V_R|}{X} (\Delta V)$$

x) Corona Discharge

factors affecting.

1. Breq. (α).
2. Sys. voltage (α).
3. conductivity of air.
4. Conductor diameter.
5. Load current.
6. cond^r surface.

x) Bus admittance matrix.



S_{Gi} → complex power injected.

S_{Pi} → complex power drawn by load.

∴ at i th bus, the power is,

$$S_i = S_{Gi} - S_{Pi}$$

$$S_{Gi} = P_{Gi} + jQ_{Gi}$$


$$S_{Pi} = P_{Pi} + jQ_{Pi}$$

Current at i th bus,

$$I_i = I_{Gi} - I_{Pi}$$

Let y_{ik} = total admittance b/w i th & k th bus

y_{io} → admittance b/w i th bus & gnd.



$$\text{Admittance } Y = \frac{1}{Z} \quad I = \frac{V}{Z} = V \cdot Y$$

Apply KCL to 4 nodes

$$I_1 = V_1 Y_{10} + (V_1 - V_2) Y_{12} + (V_1 - V_3) Y_{13}$$

$$I_2 = V_2 Y_{20} + (V_2 - V_3) Y_{23} + (V_2 - V_4) Y_{24} + (V_2 - V_1) Y_{12}$$

$$I_3 = V_3 Y_{30} + (V_3 - V_1) Y_{13} + (V_3 - V_2) Y_{23} + (V_3 - V_4) Y_{34}$$

$$I_4 = V_4 Y_{40} + (V_4 - V_3) Y_{34} + (V_4 - V_2) Y_{24}$$

$$[I_{bus}] = [Y_{bus}] [V_{bus}]$$

$$I_1 = V_1(Y_{10} + Y_{12} + Y_{13}) - V_2 Y_{12} - V_3 Y_{13}$$

$$I_2 = V_2(Y_{20} + Y_{23} + Y_{21} + Y_{24}) - V_1 Y_{21} - V_3 Y_{23} - V_4 Y_{24}$$

$$I_3 = V_3(Y_{30} + Y_{31} + Y_{32} + Y_{34}) - V_1 Y_{31} - V_2 Y_{32} - V_4 Y_{34}$$


$$I_4 = V_4(Y_{40} + Y_{43} + Y_{42}) - V_1 Y_{42} - V_3 Y_{43}$$

$$\begin{bmatrix} I_1 \\ I_2 \\ I_3 \\ I_4 \end{bmatrix} = \begin{bmatrix} Y_{11} & Y_{12} & Y_{13} & Y_{14} \\ Y_{21} & Y_{22} & Y_{23} & Y_{24} \\ Y_{31} & Y_{32} & Y_{33} & Y_{34} \\ Y_{41} & Y_{42} & Y_{43} & Y_{44} \end{bmatrix} \begin{bmatrix} V_1 \\ V_2 \\ V_3 \\ V_4 \end{bmatrix}$$

$$= \begin{bmatrix} Y_{11} & (Y_{10} + Y_{12} + Y_{13}) & -Y_{12} & -Y_{13} & 0 & 0 \\ -Y_{10} & -Y_{10} - (Y_{20} + Y_{21} + Y_{23} + Y_{24}) & -Y_{21} & -Y_{23} & -Y_{24} & 0 \\ -Y_{31} & -Y_{31} - Y_{32} & (Y_{30} + Y_{31} + Y_{32} + Y_{34}) & -Y_{32} & -Y_{34} & Y_{33} \\ 0 & 0 & -Y_{42} & Y_{43} & (Y_{40} + Y_{43} + Y_{42}) & Y_{44} \end{bmatrix}$$

diagonal elements \rightarrow self admittances

non-diagonal elements \rightarrow mutual / transfer admittances.



11

$$\begin{bmatrix} I_1 \\ I_2 \\ I_3 \end{bmatrix} = \begin{bmatrix} 0.005+10-j15+15-j10 & -10+j15 & 15-j10 \\ 10-j15 & 0.005+10-j15+15-j15 & 15-j15 \\ 15-j10 & 15-j15 & 0.007+15-j10+15-j15 \end{bmatrix}$$

$$= \begin{bmatrix} -10+j15 \\ 25.005-25j & 10+j15 & 15-j10 \\ 10+j15 & 28.005-j30 & -15+j15 \\ 15+j10 & -15+j15 & 30.007-j25 \end{bmatrix}$$

Q.	From Bus	To Bus	Resistance	Reactance	Admittances
	1	2	0	$j0.34\Omega$	$-j2.94$
	2	3	0	$j0.42\Omega$	$-j2.38$
	1	3	0	$j0.30\Omega$	$-j3.33$
	2	0	0	$j0.15\Omega$	$-j6.66$
	3	0	0	$j0.1\Omega$	$-j10$

$$\begin{bmatrix} I_1 \\ I_2 \\ I_3 \end{bmatrix} = \begin{bmatrix} -j2.94-j3.33 & j2.94 & j3.33 \\ j2.94 & -j6.66-j2.94-j2.38 & j2.38 \\ j3.33 & j2.38 & -j10-j3.33-j2.38 \end{bmatrix}$$

$$= \begin{bmatrix} -j6.27 & j2.94 & j3.33 \\ j2.94 & -j11.98 & j2.38 \\ j3.33 & j2.38 & -j15.71 \end{bmatrix}$$