DEPARTMENT OF FIRE AND RESCUE SERVICES

Office of the Chief Fire Officer - District Fire Headquarters

NOC Certificate No: FIRE-NOC-MUNI-2026-789 **Date: 15th January 2026**

CERTIFICATE OF FIRE SAFETY AND NO OBJECTION CERTIFICATE (NOC)

Certified that the institutional premises of:
Meridian Institute of Technology (PID: 1-93481203),
comprising Academic Block A, Administrative Block, and Engineering Laboratories,
was inspected on 12th January 2026 by the Divisional Fire Officer.

Findings & Fire Safety Infrastructure:
- Wet riser and hydrant system: Operational with 100,000L static reservoir.
- Automatic smoke detection and fire alarm panel: Fully functional.
- Emergency evacuation staircases: Clear with photoluminescent exit signage.
- Portable fire extinguishers: Inspected and tagged with valid expiry dates.

Validity Condition: This Fire Safety NOC is valid strictly up to 31st March 2027.

Issued under Section 13 of the Fire Prevention and Life Safety Measures Act.

Chief Fire Officer [DIGITALLY SIGNED]