

WATER QUALITY & POTABILITY TEST REPORT (IS 10500)

NABL Accredited Chemical & Microbiological Environmental Testing Lab

Document Reference:	NABL/ENV/2026/W-84920
Issuing Authority:	Apex Environmental NABL Analytical Laboratories
Issue Date:	28 September 2026
Compliance Verification:	VALID — HEURISTIC & AI VERIFIED

Water Sample Source: Industrial Borewell & Municipal Filtration System (Plot E-42 Chakan MIDC).

Parameters Tested: - pH: 7.2 (Acceptable range 6.5 - 8.5) - Total Dissolved Solids (TDS): 210 mg/L (Limit: 500 mg/L)
- Coliform & E. Coli: Absent / 100 ml - Toxic Heavy Metals (Pb, As, Hg): Below Detectable Limits

CONCLUSION: Water meets all statutory potability requirements under IS 10500:2012 for industrial food manufacturing.

This electronic document was generated by the AI Industrial Compliance & Approval Platform. Valid for SIH Hackathon Evaluation.