



 Leakage AI Report — 2 Critical Alerts Detected
1 message

SIDDHARTH SHEKHAR SINGH <connectwidsiddharth@gmail.com> Sat, May 30, 2026 at 11:30 AM
To: connectwidsiddharth@gmail.com

 Leakage AI Detector
Automated Leakage Detection Report

 Network Summary

 DMA Zones Monitored	10
 Total Readings Analysed	900
 Critical Alerts	2
 High Severity Alerts	2
 Total Anomalies	17

 Critical Alerts

- DMA_01 — Northfield**
MNF: 6.22 L/s | Pressure: 44.66m | Confidence: 100/100
Pipe burst detected. Immediate investigation required.
- DMA_05 — Greenpark**
MNF: 10.91 L/s | Pressure: 38.38m | Confidence: 100/100
Large scale burst detected. Urgent field response required.

 [View Live Dashboard](#)

Generated by Leakage AI Detector | Built by Siddharth Shekhar Singh