AS-BUILT FIELD SHEET -- VALVE STATION V-9

REVISION B

TORQUE SPEC: 60 FT-LB

NOTE: FLANGE GASKET REPLACED 2025-01-15

INSPECTED BY: R. TANAKA