

INSTRUCTIONS FOR CREATING SUBFORM: 2.16-TEC-Annual-TORFI

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Description: 2.16-A-TEC-10A: without requiring the operation of fan motors in order to prevent damage. Control sequences shall be verified throughout the system, including verification of override from the fire-fighter's control panel and simulation of standby power conditions.

Options: Yes, No

STEP 2: Create a Single Select field

Description: 2.16-A-TEC-6: Check control box for dirt, debris, and/or loose terminations. Clean and tighten electrical connections as needed.

Options: Yes, No

STEP 3: Create a Single Select field

Description: 2.16-A-TEC-8: Check to see that backup of digital control program is current. Update when it is not current.

Options: Yes, No