

INSTRUCTIONS FOR CREATING SUBFORM: 2.4-BFV-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: GSH

Description: 2.4-A-BFV-1: Inspect butterfly valve for any leaks, corrosion and seizing. Ensure valve in correct position and correct flow through device. Clean, lubricate and verify proper operation.

Options: Yes, No