

INSTRUCTIONS FOR CREATING SUBFORM: 3.4-LVXFMR-Triennial

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: UNITY

Description: 3.4-T-LVXFMR-2: Infrared scan the transformers windings and cable terminals to check for abnormal temperature conditions Tighten cable terminations, evaluate electrical loading on transformer using ampacity meter.

Options: Yes, No