

INSTRUCTIONS FOR CREATING SUBFORM: 2.16-ACR-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: GSH

Description: 2.16-A-ACR-1: Check control box for dirt, debris, and/or loose terminations. Clean and tighten electrical connections as needed.

Options: Yes, No

STEP 2: Create a Single Select field

Contractor: GSH

Description: 2.16-A-ACR-10: Check motor contactor for pitting or other signs of damage. Clean and tighten electrical connections as needed.

Options: Yes, No

STEP 3: Create a Single Select field

Contractor: GSH

Description: 2.16-A-ACR-2: Check integrity of all panels on equipment. Replace fasteners as needed to ensure proper integrity and fit/finish of equipment.

Options: Yes, No

STEP 4: Create a Single Select field

Contractor: GSH

Description: 2.16-A-ACR-6: Check fan drive for problems due to poor alignment or poor bearing seating. Adjust and lubricate as necessary.

Options: Yes, No

STEP 5: Create a Single Select field

Contractor: GSH

Description: 2.16-A-ACR-7: Check fan blades and fan housing. Clean as needed.

Options: Yes, No

STEP 6: Create a Single Select field

Contractor: GSH

Description: 2.16-A-ACR-8: Assess field-serviceable bearings. Lubricate as necessary.

Options: Yes, No

STEP 7: Create a Single Select field

Contractor: GSH

Description: 2.16-A-ACR-9: Check control box for dirt, debris, and/or loose terminations. Clean and tighten electrical connections as needed.

Options: Yes, No