

INSTRUCTIONS FOR CREATING SUBFORM: 2.3-FT-Monthly

Follow these steps to create the form fields:

STEP 1: Create an Info Text field

Content: GSH

STEP 2: Create a Single Select field

Description: 2.3-M-FT-1: Inspect flash tank to ensure it is secured and is not vibrating excessively. Secure flash tank. If flash tank continues to vibrate, condensate lines and/or flash vessel may be undersized or water hammer occurring. Contact manufacturer.

Options: Yes, No

STEP 3: Create a Single Select field

Description: 2.3-M-FT-2: Check for proper flash steam flow. Adjust pressure reducing valve or back pressure regulator as necessary, if excessive or inadequate.

Options: Yes, No

STEP 4: Create a Single Select field

Description: 2.3-M-FT-3: Inspect back pressure regulator. Adjust back pressure regulator and/or pressure reducing valve steam pressure setting, if back pressure regulator is venting too often.

Options: Yes, No

STEP 5: Create a Single Select field

Description: 2.3-M-FT-4: Check flash tank for flooding. Isolate and check traps and discharge check valve.

Options: Yes, No