

## INSTRUCTIONS FOR CREATING SUBFORM: 2.4-RPZ-Quarterly

**Follow these steps to create the form fields:**

### **STEP 1: Create a Single Select field**

**Description:** 2.4-Q-RPZ-1: Inspect reduced pressure zone valve assembly to ensure isolation valves are in the normal open position. Place the isolation valves in the normal open position.

**Options:** Yes, No

### **STEP 2: Create a Single Select field**

**Description:** 2.4-Q-RPZ-2: Inspect reduced pressure zone valve assembly to ensure that the differential- sensing valve relief port is not continuously discharging.

**Options:** Yes, No

### **STEP 3: Create a Single Select field**

**Description:** 2.4-Q-RPZ-2A: Record continuous discharge. Internal components shall be cleaned, repaired, replaced, lubricated and cleared of obstructions as necessary in accordance with the manufacturer's instructions.

**Options:** Yes, No