

# INSTRUCTIONS FOR CREATING SUBFORM: 2.16-SPP-Annual

**Follow these steps to create the form fields:**

## **STEP 1: Create a Single Select field**

**Description:** 2.16-A-SPP-10B: A record of each inspection and test shall be maintained on the premises as required per NYC BC 909.3.1. Lubricate and align as needed.

**Options:** Yes, No

## **STEP 2: Create a Single Select field**

**Description:** 2.16-A-SPP-10: For Smoke Exhaust System: Each smoke zone, equipped with an automatic-initiation device, shall be put into operation by the actuation of one such device. Each additional device within the zone shall be verified to cause the same sequence

**Options:** Yes, No

## **STEP 3: Create a Single Select field**

**Description:** 2.16-A-SPP-10A: without requiring the operation of fan motors in order to prevent damage. Control sequences shall be verified throughout the system, including verification of override from the fire-fighter's control panel and simulation of standby power conditions.

**Options:** Yes, No

## **STEP 4: Create a Single Select field**

**Description:** 2.16-A-SPP-6: Check control box for dirt, debris, and/or loose terminations. Clean and tighten electrical connections as needed.

**Options:** Yes, No

## **STEP 5: Create a Single Select field**

**Description:** 2.16-A-SPP-8: Check to see that backup of digital control program is current. Update when it is not current.

**Options:** Yes, No

## **STEP 6: Create a Single Select field**

**Description:** 2.16-A-SPP-7: Check motor contactor for pitting or other signs of damage. Clean and tighten electrical connections as needed.

**Options:** Yes, No