

## INSTRUCTIONS FOR CREATING SUBFORM: 5.4-AHV-Annual

**Follow these steps to create the form fields:**

### **STEP 1: Create a Single Select field**

**Contractor:** UFCO

**Description:** 5.4-A-AHV-2: Perform test on hose valve.

**Options:** Yes, No

### **STEP 2: Create a Single Select field**

**Contractor:** UFCO

**Description:** 5.4-A-AHV-2A: Hose valves shall be tested by fully opening and closing the valves. Hose valves can be tested without a full flow if the cap is left on the hose threads. The purpose of this requirement is to exercise the valve so it can be operated easily.

**Options:** Yes, No