

INSTRUCTIONS FOR CREATING SUBFORM: 2.7-SPF-Semi-Annual

Follow these steps to create the form fields:

STEP 1: Create an Info Text field

Content: GSH

STEP 2: Create a Single Select field

Contractor: GSH

Description: 2.7-SA-SPF-1: Check fan-belt tension, check for belt wear, and check sheaves for evidence of improper alignment or evidence of wear. Fans shall be examined for correct rotation.

Options: Yes, No

STEP 3: Create a Single Select field

Contractor: GSH

Description: 2.7-SA-SPF-1A: Measurements of voltage, amperage, revolutions per minute (rpm) and belt tension shall be made. Correct tension and sheave alignment. A record of each inspection and test shall be maintained on the premises as required per NYC BC 909.3.1.

Options: Yes, No

STEP 4: Create an Info Text field

Content: TORFI/GSH

STEP 5: Create a Single Select field

Contractor: TORFI/GSH

Description: 2.7-SA-SPF-2: Check variable-frequency drive or motor starter for proper operation. Correct as needed. Clean housing, and tighten connections as needed. Clean or replace air filter.

Options: Yes, No

STEP 6: Create an Info Text field

Content: TORFI

STEP 7: Create a Single Select field

Contractor: TORFI

Description: 2.7-SA-SPF-3: Check control system and devices for evidence of improper operation. Clean, lubricate, adjust.

Options: Yes, No