INSTRUCTIONS FOR CREATING SUBFORM: 2.7-SPF-Semi-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Description: 2.7-SA-SPF-1: Check fan-belt tension, check for belt wear, and check sheaves for evidence of improper alignment or evidence of wear. Fans shall be examined for correct rotation.

Options: Yes, No

STEP 2: Create a Single Select field

Description: 2.7-SA-SPF-1A: Measurements of voltage, amperage, revolutions per minute (rpm) and belt tension shall be made. Correct tension and sheave alignment. A record of each inspection and test shall be maintained on the premises as required per NYC BC 909.3.1.

Options: Yes, No

STEP 3: Create a Single Select field

Description: 2.7-SA-SPF-2: Check variable-frequency drive or motor starter for proper operation. Correct as needed. Clean housing, and tighten connections as needed. Clean or replace air filter.

Options: Yes, No