

INSTRUCTIONS FOR CREATING SUBFORM: 7.4-R&G.LAD-Annual;

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Description: 7.4-A-R&G.LAD-1;; Inspect ladders for: Anchorage, any obstructions behind the ladder within the required clearances, the extension grab bar at the top of the ladder 1. Check the ladder is securely fastened to the wall replace anchors as required.

Options: Yes, No

STEP 2: Create a Single Select field

Description: 7.4-A-R&G.LAD-1A;; 2. If conduits or other interferences within the 7" is noticed, they should be removed or rerouted.3. Grab bar should be extended up to make sure it is still functioning as designed.

Options: Yes, No