

INSTRUCTIONS FOR CREATING SUBFORM: 5.2-SDWU-Annual

Follow these steps to create the form fields:

STEP 1: Create an Info Text field

Content: United Fire

STEP 2: Create a Single Select field

Description: 5.2-A-SDWU-2: Test in place to ensure smoke entry into sensing chamber and an alarmed response. Canned smoke approved for use in NYC will be sprayed into the detector's sensing chamber, Detector's red led and remote LED should light steady.

Options: Yes, No