

INSTRUCTIONS FOR CREATING SUBFORM: 2.3-GMU-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: GSH

Description: 2.3-A-GMU-10: Check insulation, vibration isolators, and flexible connectors for integrity. Clean as needed. Record location of damage.

Options: Yes, No

STEP 2: Create a Single Select field

Contractor: GSH

Description: 2.3-A-GMU-6: Check motor contactor for pitting or other signs of damage. Clean and tighten electrical connections as needed.

Options: Yes, No

STEP 3: Create a Single Select field

Contractor: GSH

Description: 2.3-A-GMU-7: Check pump drive for wear or problems due to poor alignment or poor bearing seating. Lubricate and adjust, and record evidence of wear.

Options: Yes, No

STEP 4: Create a Single Select field

Contractor: GSH

Description: 2.3-A-GMU-8: Check for proper fluid flow. Clean, adjust, and repair as needed to restore proper flow. Clean, adjust, as needed to restore proper flow.

Options: Yes, No

STEP 5: Create a Single Select field

Contractor: GSH

Description: 2.3-A-GMU-9: Assess field-serviceable bearings. Lubricate as necessary.

Options: Yes, No