

INSTRUCTIONS FOR CREATING SUBFORM: 5.5-DSCVA-Triennial

Follow these steps to create the form fields:

STEP 1: Create an Info Text field

Content: United Fire

STEP 2: Create a Single Select field

Description: 5.5-T-DSCVA-9: Perform test on quick opening device.

Options: Yes, No

STEP 3: Create a Single Select field

Description: 5.5-T-DSCVA-13: Perform gas leakage test. Dry pipe systems shall be tested for gas leakage, using one of the following test methods:(1) A gas (air or nitrogen) pressure test at 40psi (3.2 bar)shall be performed for 2 hours.

Options: Yes, No

STEP 4: Create a Single Select field

Description: 5.5-T-DSCVA-13A: (a) The system shall be permitted to lose up to 3 psi(0.2 bar) during the duration of the test.(b) Gas leaks shall be addressed if the system loses more than 3 psi (0.2 bar) during this test.

Options: Yes, No