

INSTRUCTIONS FOR CREATING SUBFORM: 2.3-HX(ST)-Semi-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: GSH

Description: 2.3-SA-HX(ST)-2: Check for evidence of build-up, fouling, corrosion, or degradation on tube heat exchange surfaces. Clean and restore as needed to ensure acceptable condition.

Options: Yes, No