

# INSTRUCTIONS FOR CREATING SUBFORM: 5.4-DSCVA-Monthly

**Follow these steps to create the form fields:**

## **STEP 1: Create a Single Select field**

**Description:** 5.4-M-DSCVA-3: Inspect pressure gauges. Ensure the gauge on the supply side of the dry pipe valve shall indicate that the normal supply water pressure is being maintained

**Options:** Yes, No

## **STEP 2: Create a Single Select field**

**Description:** 5.4-M-DSCVA-3A: the gauge on the system side of the dry pipe valve shall indicate that the proper ratio of air or nitrogen pressure to water supply pressure is being maintained in accordance with the manufacturer's instructions and the gauge on the quick-opening device

**Options:** Yes, No

## **STEP 3: Create a Single Select field**

**Description:** 5.4-M-DSCVA-3B: if provided, shall indicate the same pressure as the gauge on the system side of the dry pipe valve.

**Options:** Yes, No

## **STEP 4: Create a Single Select field**

**Description:** 5.4-M-DSCVA-4: Inspect valve assembly to verify the following: (1) The valve is free of physical damage. (2) All trim valves are in the appropriate open or closed position.

**Options:** Yes, No

## **STEP 5: Create a Single Select field**

**Description:** 5.4-M-DSCVA-4A: 3) The intermediate chamber is not leaking. Record any locations with damage, positions of trim valves and any leaks.

**Options:** Yes, No