

## INSTRUCTIONS FOR CREATING SUBFORM: 5.3-FM200-Quinquennial

**Follow these steps to create the form fields:**

### **STEP 1: Create an Info Text field**

**Content:** United Fire

### **STEP 2: Create a Single Select field**

**Description:** 5.3-QQ-FM200-12: Perform a retest and complete visual inspection of storage containers as described in NFPA 2001 - Section 8.6.

**Options:** Yes, No

### **STEP 3: Create a Single Select field**

**Description:** 5.3-QQ-FM200-12A: Record any damage to storage containers, date and location. Perform additional strength tests in accordance with transportation regulations, if damaged.

**Options:** Yes, No

### **STEP 4: Create a Single Select field**

**Description:** 5.3-QQ-FM200-13: Perform test of system hoses as per NFPA 2001 - Section 8.7. Record results of tests, date and location. Alternatively replace system hoses.

**Options:** Yes, No