

INSTRUCTIONS FOR CREATING SUBFORM: 3.4-MVCB-Triennial

Follow these steps to create the form fields:

STEP 1: Create an Info Text field

Content: UNITY

STEP 2: Create a Single Select field

Description: 3.4-T-MVCB-3: Perform contract resistance test

Options: Yes, No

STEP 3: Create a Single Select field

Description: 3.4-T-MVCB-4: Verify trip, close, trip-free and anti-pump function

Options: Yes, No

STEP 4: Create a Single Select field

Description: 3.4-T-MVCB-5: Trip circuit breaker by operation of each protective device

Options: Yes, No

STEP 5: Create a Single Select field

Description: 3.4-T-MVCB-6: Perform insulation resistance test, pole-to-pole, pole-to-ground and across open poles

Options: Yes, No