

INSTRUCTIONS FOR CREATING SUBFORM: 5.2-EOL6.8K-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Description: 5.2-A-EOL6.8K-2: With each initiating circuit conductor pair short-circuited at the far end, the resistance of each circuit shall be measured and recorded. It shall be verified that the loop resistance does not exceed the limits of the EOL.

Options: Yes, No