

INSTRUCTIONS FOR CREATING SUBFORM: 2.16-RIP-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Description: 2.16-A-RIP-10: Verify actuator movement and device response to control output. Lubricate and align as needed. *task with equipment controlled

Options: Yes, No

STEP 2: Create a Single Select field

Description: 2.16-A-RIP-7: Check motor contactor for pitting or other signs of damage. Clean and tighten electrical connections as needed.

Options: Yes, No