

INSTRUCTIONS FOR CREATING SUBFORM: 5.2-SD.ASD-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: UFCO

Description: 5.2-A-SD.ASD-2: Perform test methods as documented in the manufacturer's published instructions. Detector alarm response shall be verified through the end sampling port on each pipe run. Airflow through other ports shall be verified as well.

Options: Yes, No