

INSTRUCTIONS FOR CREATING SUBFORM: 3.3-GEN-Semi-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: UNITY/PENN

Description: 3.3-SA-GEN-1: Check engine valve lash every 250 hours of service. Make note of any deficiencies and address before next scheduled maintenance.

Options: Yes, No

STEP 2: Create a Single Select field

Contractor: UNITY/PENN

Description: 3.3-SA-GEN-2: Test air shutoff every 250 service hours. Make note of any deficiencies and address before next scheduled maintenance.

Options: Yes, No

STEP 3: Create a Single Select field

Contractor: UNITY/PENN

Description: 3.3-SA-GEN-3: Obtain engine oil sample every 250 service hours. Make note of oil quality and replace as necessary.

Options: Yes, No

STEP 4: Create a Single Select field

Contractor: UNITY/PENN

Description: 3.3-SA-GEN-60: Obtain Coolant Sample Test Results (Level 1). Refer to TSOW for Level 1 procedure.

Options: Yes, No

STEP 5: Create a Single Select field

Contractor: UNITY/PENN

Description: 3.3-SA-GEN-61: Check Stator Lead

Options: Yes, No