

## INSTRUCTIONS FOR CREATING SUBFORM: 2.16-ATT-ST-Annual

**Follow these steps to create the form fields:**

### **STEP 1: Create an Info Text field**

**Content:** GSH

### **STEP 2: Create a Single Select field**

**Description:** 2.16-A-ATT-ST-1: Verify that Perforated sheet metal liner and baffles are undamaged, remaining parallel, airspaces between baffles are free of debris, holes in perforated sheet metal liner are open and free of dust and foreign matter, no signs of rusting

**Options:** Yes, No

### **STEP 3: Create a Single Select field**

**Description:** 2.16-A-ATT-ST-1A: Vacuum dry deposits from airspaces and sheet metal liner. Remove grease laden deposits with mild detergent solution or isopropyl water base solution

**Options:** Yes, No

### **STEP 4: Create a Single Select field**

**Description:** 2.16-A-ATT-ST-3: Inspect sound attenuator for signs of corrosion, defects or cracks. Record location of damage.

**Options:** Yes, No

### **STEP 5: Create a Single Select field**

**Description:** 2.16-A-ATT-ST-4: Check attenuator for dirt, debris, and/or damaged/loose flexible connections. Clean attenuator and tighten/replace connections as needed.

**Options:** Yes, No