

INSTRUCTIONS FOR CREATING SUBFORM: 5.5-DSCVA-Monthly

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: UFCO

Description: 5.5-M-DSCVA-3: Inspect pressure gauges. Ensure the gauge on the supply side of the dry pipe valve shall indicate that the normal supply water pressure is being maintained,

Options: Yes, No

STEP 2: Create a Single Select field

Contractor: UFCO

Description: 5.5-M-DSCVA-3A: the gauge on the system side of the dry pipe valve shall indicate that the proper ratio of air or nitrogen pressure to water supply pressure is being maintained in accordance with the manufacturer's instructions and the gauge on the quick-opening device

Options: Yes, No

STEP 3: Create a Single Select field

Contractor: UFCO

Description: 5.5-M-DSCVA-3B: if provided, shall indicate the same pressure as the gauge on the system side of the dry pipe valve.

Options: Yes, No

STEP 4: Create a Single Select field

Contractor: UFCO

Description: 5.5-M-DSCVA-4: Inspect valve assembly to verify the following: (1) The valve is free of physical damage. (2) All trim valves are in the appropriate open or closed position. (3) The intermediate chamber is not leaking.

Options: Yes, No

STEP 5: Create a Single Select field

Contractor: UFCO

Description: 5.5-M-DSCVA-4A: Record any locations with damage, positions of trim valves and any leaks.

Options: Yes, No