

INSTRUCTIONS FOR CREATING SUBFORM: 3.4-LVCB-Triennial

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: UNITY

Description: 3.4-T-LVCB-3: Verify trip, close, trip-free and anti-pump function

Options: Yes, No

STEP 2: Create a Single Select field

Contractor: UNITY

Description: 3.4-T-LVCB-4: Trip circuit breaker by operation of each protective device

Options: Yes, No

STEP 3: Create a Single Select field

Contractor: UNITY

Description: 3.4-T-LVCB-5: Trip circuit breaker by operation of each protective device

Options: Yes, No

STEP 4: Create a Single Select field

Contractor: UNITY

Description: 3.4-T-LVCB-6: Perform insulation resistance test, pole-to- pole, pole-to-ground and across open poles

Options: Yes, No