

INSTRUCTIONS FOR CREATING SUBFORM: 5.4-FC-Semi-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: UFCO

Description: 5.4-SA-FC-4: Perform test of supervisory switches. The signal shall not be restored at any valve position except the normal position.

Options: Yes, No

STEP 2: Create a Single Select field

Contractor: UFCO

Description: 5.4-SA-FC-4A: A distinctive signal shall indicate movement from the valve's normal position during either the first two revolutions of a hand wheel or when the stem of the valve has moved one-fifth of the distance from its normal position.

Options: Yes, No

STEP 3: Create a Single Select field

Contractor: UFCO

Description: 5.4-SA-FC-5: Perform test on waterflow switch. Test shall be accomplished by opening the inspector's test connection. Where freezing weather conditions or other circumstances prohibit use of the inspector's test connection,

Options: Yes, No

STEP 4: Create a Single Select field

Contractor: UFCO

Description: 5.4-SA-FC-5A: the bypass connection shall be permitted to be used. Testing waterflow alarm devices on dry pipe, preaction, or deluge systems shall be accomplished by using the bypass connection.

Options: Yes, No