

INSTRUCTIONS FOR CREATING SUBFORM: 7.4-R&G.AH-Annual;

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Description: 7.4-A-R&G.AH-1;; Inspect the fire rated wall access hatches and hardware for damage. Inspect doors to confirm there is no violation of NFPA 80 door checklist. Check the UL labels on the door and frame are present and not covered

Options: Yes, No

STEP 2: Create a Single Select field

Description: 7.4-A-R&G.AH-1A;; Replace hardware as required. If door panel fails the NFPA 80 checklist, the door should be replaced. Replace/clear UL door labels.

Options: Yes, No