INSTRUCTIONS FOR CREATING SUBFORM: 3.4-MVSWGR-Triennial

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: UNITY

Description: 3.4-T-MVSWGR-2: Infrared scan the switchgear bus work and cable terminals to check for abnormal temperature conditions. Tighten cable termnations and bus connectinos bolts. Evaluate if bus loading is contributing to the overheating.

Options: Yes, No