

## INSTRUCTIONS FOR CREATING SUBFORM: 3.3-GEN-Semi-Annual

**Follow these steps to create the form fields:**

### **STEP 1: Create a Single Select field**

**Description:** 3.3-SA-GEN-1: Check engine valve lash every 250 hours of service. Make note of any deficiencies and address before next scheduled maintenance.

**Options:** Yes, No

### **STEP 2: Create a Single Select field**

**Description:** 3.3-SA-GEN-2: Test air shutoff every 250 service hours. Make note of any deficiencies and address before next scheduled maintenance.

**Options:** Yes, No

### **STEP 3: Create a Single Select field**

**Description:** 3.3-SA-GEN-3: Obtain engine oil sample every 250 service hours. Make note of oil quality and replace as necessary.

**Options:** Yes, No

### **STEP 4: Create a Single Select field**

**Description:** 3.3-SA-GEN-60: Obtain Coolant Sample Test Results (Level 1). Refer to TSOW for Level 1 procedure.

**Options:** Yes, No

### **STEP 5: Create a Single Select field**

**Description:** 3.3-SA-GEN-61: Check Stator Lead

**Options:** Yes, No