INSTRUCTIONS FOR CREATING SUBFORM: 3.8-UPSR3KVA-Quarterly

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Description: 3.8-Q-UPSR3KVA-1: Visual inspection of environment for

signs of impact to proper UPS operation

Options: Yes, No

STEP 2: Create a Single Select field

Description: 3.8-Q-UPSR3KVA-10: Clean and vacuum UPS equipment

enclosures

Options: Yes, No

STEP 3: Create a Single Select field

Description: 3.8-Q-UPSR3KVA-11: Perform any additional maintenance

according to manufacturer's recommendations

Options: Yes, No

STEP 4: Create a Single Select field

Description: 3.8-Q-UPSR3KVA-12: Documents and advise customer of all

findings

Options: Yes, No

STEP 5: Create a Single Select field

Description: 3.8-Q-UPSR3KVA-13: Review equipment operation and

vent/fault history with customer

Options: Yes, No

STEP 6: Create a Single Select field

Description: 3.8-Q-UPSR3KVA-14: Develop a remedial action plan with

customer to address major issues

Options: Yes, No

STEP 7: Create a Single Select field

Description: 3.8-Q-UPSR3KVA-2: Verification of proper software versions

and all adjustable parameters Update software as needed.

Options: Yes, No

STEP 8: Create a Single Select field

Description: 3.8-Q-UPSR3KVA-3: Verification of proper cooling fan

operation

Options: Yes, No

STEP 9: Create a Single Select field

Description: 3.8-Q-UPSR3KVA-4: Verification of proper display of system

values

Options: Yes, No

STEP 10: Create a Single Select field

Description: 3.8-Q-UPSR3KVA-5: Review event/fault history menus

Documents and advise customer of all findings

Options: Yes, No

STEP 11: Create a Single Select field

Description: 3.8-Q-UPSR3KVA-8: Inspect battery connections Repair

battery connections as needed

Options: Yes, No

STEP 12: Create a Single Select field

Description: 3.8-Q-UPSR3KVA-9: Visually check for liquid contamination

from batteries and capacitors

Options: Yes, No