

INSTRUCTIONS FOR CREATING SUBFORM: 5.5-DSCVA-Quinquennial

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Description: 5.5-QQ-DSCVA-6: Inspect strainers, filters, and restricted orifices internally. Internal components shall be cleaned, repaired, replaced and cleared of obstructions as necessary in accordance with the manufacturer's instructions.

Options: Yes, No