INSTRUCTIONS FOR CREATING SUBFORM: 2.4-NFWH-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: GSH

Description: 2.4-A-NFWH-1: Inspect non-freeze wall hydrant for any leaks, corrosion and seizing. Clean, lubricate and verify proper operation.

Options: Yes, No