

INSTRUCTIONS FOR CREATING SUBFORM: 5.5-FHV-Quarterly

Follow these steps to create the form fields:

STEP 1: Create an Info Text field

Content: United Fire

STEP 2: Create a Single Select field

Description: 5.5-Q-FHV-1: Inspect hose valves to ensure the following: (1) Hose caps are in place and not damaged. (2) Hose threads are not damaged.(3) Valve handles are present and not damaged.(4) Gaskets are not damaged or showing signs of deterioration.(5) No leaks are present.

Options: Yes, No

STEP 3: Create a Single Select field

Description: 5.5-Q-FHV-1A: (6) Valves are not obstructed or otherwise not capable of normal operation. Record locations and components that are damaged, deteriorating or leaking. Remove any obstructions. Place valve caps in proper position.

Options: Yes, No