

INSTRUCTIONS FOR CREATING SUBFORM: 2.16-CB-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: UNITY

Description: 2.16-A-CB-1: Inspect for cracks in the case. Inspect for loose connections or evidence of overheating. Maintain clean of external contamination.

Options: Yes, No

STEP 2: Create a Single Select field

Contractor: UNITY

Description: 2.16-A-CB-2: Inspect for loose connections or evidence of overheating. Tighten loose connections as required.

Options: Yes, No

STEP 3: Create a Single Select field

Contractor: UNITY

Description: 2.16-A-CB-3: Manually operate and trip the breaker to exercise the tripping mechanisms.

Options: Yes, No