

INSTRUCTIONS FOR CREATING SUBFORM: 2.16-ACU(TEC)-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Description: 2.16-A-ACU(TEC)-6: Check control box for dirt, debris, and/or loose terminations. Clean and tighten electrical connections as needed.

Options: Yes, No

STEP 2: Create a Single Select field

Description: 2.16-A-ACU(TEC)-10: Verify actuator movement and device response to control output. Lubricate and align as needed.

Options: Yes, No

STEP 3: Create a Single Select field

Description: 2.16-A-ACU(TEC)-8: Check to see that backup of digital control program is current. Update when it is not current.

Options: Yes, No

STEP 4: Create a Single Select field

Description: 2.16-A-ACU(TEC)-11: Change Automatic Temperature Control (ATC) interface user authentication passwords. Make the change.

*RECOMMEND AGAINST

Options: Yes, No

STEP 5: Create a Single Select field

Description: 2.16-A-ACU(TEC)-7: Check motor contactor for pitting or other signs of damage. Clean and tighten electrical connections as needed.

Options: Yes, No

STEP 6: Create a Single Select field

Description: 2.16-A-ACU(TEC)-9: Check battery backup and verify proper operation. Clean and maintain batteries as needed.

Options: Yes, No