

INSTRUCTIONS FOR CREATING SUBFORM: 2.7-ACCU-Semi-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Description: 2.7-SA-ACCU-1: Check control system and devices for evidence of improper operation. Clean, lubricate, adjust.

Options: Yes, No

STEP 2: Create a Single Select field

Description: 2.7-SA-ACCU-2: Check fan-belt tension, check for belt wear, and check sheaves for evidence of improper alignment or evidence of wear. Correct tension and sheave alignment.

Options: Yes, No

STEP 3: Create a Single Select field

Description: 2.7-SA-ACCU-3: Check variable-frequency drive for proper operation. Correct as needed. Clean housing & tighten connections as needed. Clean or replace air filter.

Options: Yes, No