

INSTRUCTIONS FOR CREATING SUBFORM: 2.16-SEF-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Description: 2.16-A-SEF-10: Inspect exposed ductwork and external piping for insulation and vapor barrier integrity. Record location of damage.

Options: Yes, No

STEP 2: Create a Single Select field

Description: 2.16-A-SEF-12: Inspect flexible connections. Clean as needed.

Options: Yes, No

STEP 3: Create a Single Select field

Description: 2.16-A-SEF-4: Check fan drive for problems due to poor alignment or poor bearing seating. Adjust and lubricate as necessary.

Options: Yes, No

STEP 4: Create a Single Select field

Description: 2.16-A-SEF-5: Check fan blades and fan housing. Fans shall be examined for correct rotation. Measurements of voltage, amperage, and revolutions per minute (rpm) shall be made.

Options: Yes, No

STEP 5: Create a Single Select field

Description: 2.16-A-SEF-5A: Clean as needed. A record of each inspection and test shall be maintained on the premises as required per NYC BC 909.3.1.

Options: Yes, No

STEP 6: Create a Single Select field

Description: 2.16-A-SEF-6: Assess field-serviceable bearings. Lubricate as necessary.

Options: Yes, No

STEP 7: Create a Single Select field

Description: 2.16-A-SEF-7: Check control box for dirt, debris, and/or loose terminations. Clean and tighten electrical connections as needed.

Options: Yes, No

STEP 8: Create a Single Select field

Description: 2.16-A-SEF-8: Check motor contactor for pitting or other signs of damage. Clean and tighten electrical connections as needed.

Options: Yes, No

STEP 9: Create a Single Select field

Description: 2.16-A-SEF-9: Check integrity of all panels on equipment. Replace fasteners as needed to ensure proper integrity and fit/finish of equipment.

Options: Yes, No

STEP 10: Create a Single Select field

Description: 2.16-A-SEF-11: Check damper for condition, setting, and operation. Adjust and lubricate as necessary.

Options: Yes, No

