

INSTRUCTIONS FOR CREATING SUBFORM: 5.5-FDC-Quinquennial

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: UFCO

Description: 5.5-QQ-FDC-2: Test the fire department connection Fire department check valve shall be hydrostatically tested at 150 psi (10 bar) for 2 hours.

Options: Yes, No