

INSTRUCTIONS FOR CREATING SUBFORM: 5.5-DCDA-Monthly

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: UFCO

Description: 5.5-M-DCDA-1: Inspect double check detection assembly to ensure isolation valves are in the normal open position. Place the isolation valves in the normal open position.

Options: Yes, No