

INSTRUCTIONS FOR CREATING SUBFORM: 2.14-PCP-Monthly

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: CONTRACTOR SPECIFIC

Description: 2.14-M-PCP-1: Check variable-frequency drive or motor starter for proper operation. Verify no equipment has been left in override (hand/OFF instead of auto). Make corrections as required. Clean housing, and tighten connections as needed. Clean or replace air filter.

Options: Yes, No